

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12448					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9223207875				
Technician Name :	Mayur Yadav		Technician Mobile :	8411951301	
Ticket Type :	Complain	Date & Time :	14-08-2024 01:34:44		
Vendor Details :					
Company Name/Client Name :	Shoppers Stop Ltd - HO	Customer's Mobile :	9223207875	Name :	Nandu Sir
Address :					
Mumbai , , , , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Fire				
Complain :	2nd floor fire panel fault need to clear				
Technician Comment :	5 nos smoke detector with base require				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	5 nos smoke detector with base require				

Status History :	Date Time	Technician Name	Status	Remark	Sign
	14-12-2024 06:39:46	MayurYadav	Completed	5 nos smoke detector with base require	
	14-12-2024 10:52:05	MayurYadav	New		-
	09-11-2024 06:56:55	MayurYadav	In Progress	Loop 1loop 2 second floor SSL loop open and short issue resolved and detector issue 3 but on under observation for other detector fault	
	09-11-2024 10:21:27	MayurYadav	New		-
	19-10-2024 11:04:33	MayurYadav	New		-
	28-09-2024 10:24:04	MayurYadav	New		-
	21-09-2024 11:45:54	MayurYadav	New		-
	17-08-2024 03:37:20	MayurYadav	Work Pending	2nd floor fire panel check our side requirement drawing for cabling and both zone open showing in panel and zone 1 check all detector and 3 joint cable in floor bcz detector Remove in floor	
	17-08-2024 11:41:46	MayurYadav	New		-
Previous Complain History :	Date Time	Technician Name	Remark		
	30-12-2024 01:09:52	Rahul Mhapralkar			
	28-12-2024 11:46:19	Shiva Meena	35 miter cebling work done and handover cebal 35 miter patil sir		