




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE3490																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9223207875																								
Technician Name :	Mayur Yadav		Technician Mobile :	8411951301																					
Ticket Type :	Complain	Date & Time :	24-07-2021 03:11:05																						
Vendor Details :																									
Company Name/Client Name :	Shoppers Stop Ltd - HO	Customer's Mobile :	9223207875	Name :	Nandu Sir																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Fire																								
Complain :	False alarm issue																								
Technician Comment :	fire panel false alarm issue solve USB extender reconnect mouse star working																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	fire panel false alarm issue solve USB extender reconnect mouse star working																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>24-07-2021 03:18:32</td><td>MayurYadav</td><td>Completed</td><td>fire panel false alarm issue solve USB extender reconnect mouse star working</td><td></td></tr><tr><td>24-07-2021 03:11:20</td><td>MayurYadav</td><td>New</td><td></td><td>-</td></tr><tr><td>24-07-2021 03:11:05</td><td>MayurYadav</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	24-07-2021 03:18:32	MayurYadav	Completed	fire panel false alarm issue solve USB extender reconnect mouse star working		24-07-2021 03:11:20	MayurYadav	New		-	24-07-2021 03:11:05	MayurYadav	New		-
Date Time	Technician Name	Status	Remark	Sign																					
24-07-2021 03:18:32	MayurYadav	Completed	fire panel false alarm issue solve USB extender reconnect mouse star working																						
24-07-2021 03:11:20	MayurYadav	New		-																					
24-07-2021 03:11:05	MayurYadav	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>03-08-2023 10:55:52</td><td>Atique Salmani</td><td>11 dome 6 fish eye with pole bracket total cameras 17 3rd and 5th boath 6 Poe swich 3nos on third and 3 nos on 5th 32 channel NVR cable approx 550 meter And patil sir required old NVR 3 floor camera in 1 NVR and 5 th floor in 1 NVR</td></tr><tr><td>29-07-2023 02:21:56</td><td>Ravi Rajbhar</td><td>1- 3rd floor main enterance biometric access divice scanner check our side ok working done but nandu sir they said sometimes it doesn't work divice 2- 5th floor it room sarver room em lock issue resloved only mainget paty propely fitting our side</td></tr></tbody></table>					Date Time	Technician Name	Remark	03-08-2023 10:55:52	Atique Salmani	11 dome 6 fish eye with pole bracket total cameras 17 3rd and 5th boath 6 Poe swich 3nos on third and 3 nos on 5th 32 channel NVR cable approx 550 meter And patil sir required old NVR 3 floor camera in 1 NVR and 5 th floor in 1 NVR	29-07-2023 02:21:56	Ravi Rajbhar	1- 3rd floor main enterance biometric access divice scanner check our side ok working done but nandu sir they said sometimes it doesn't work divice 2- 5th floor it room sarver room em lock issue resloved only mainget paty propely fitting our side											
Date Time	Technician Name	Remark																							
03-08-2023 10:55:52	Atique Salmani	11 dome 6 fish eye with pole bracket total cameras 17 3rd and 5th boath 6 Poe swich 3nos on third and 3 nos on 5th 32 channel NVR cable approx 550 meter And patil sir required old NVR 3 floor camera in 1 NVR and 5 th floor in 1 NVR																							
29-07-2023 02:21:56	Ravi Rajbhar	1- 3rd floor main enterance biometric access divice scanner check our side ok working done but nandu sir they said sometimes it doesn't work divice 2- 5th floor it room sarver room em lock issue resloved only mainget paty propely fitting our side																							