


# Vallabh Enterprises

**Regd. Office :** 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
**Support : | W :** www.vallabhenterprises.com  
**E :** vallabhsecure@yahoo.co.in

<b>Service Status Details : VE3637</b>					
<b>Priority :</b>	Low				
<b>Created By :</b>	Admin - Apurva Vajaria				
<b>Complaint Mob. No. :</b>	9223207875				
<b>Technician Name :</b>	Mayur Yadav		<b>Technician Mobile :</b>	8411951301	
<b>Ticket Type :</b>	New Installation	<b>Date &amp; Time :</b>	14-08-2021 10:11:01		
<b>Vendor Details :</b>					
Company Name/Client Name :	Shoppers Stop Ltd - HO	Customer's Mobile :	9223207875	Name :	Nandu Sir
<b>Address :</b>					
Mumbai , , , , Maharashtra					
<b>AMC Details :</b>					
Expiry Date :	01-01-1970 05:30:00		Type :		
<b>Product Name :</b>	Fire				
<b>Complain :</b>	need to install fire panel				
<b>Technician Comment :</b>	old fire panel from 3rd floor remove with all accessories and install at 2nd floor new fire panel install at 3rd floor and programming done battery missing fault and detector fault for device above ceiling keys handover to patil sir				
<b>Complain Operator :</b>	Desktop - Apurva Vajaria				
<b>Remark :</b>	old fire panel from 3rd floor remove with all accessories and install at 2nd floor new fire panel install at 3rd floor and programming done battery missing fault and detector fault for device above ceiling keys handover to patil sir				
<b>Status History :</b>	<b>Date Time</b>	<b>Technician Name</b>	<b>Status</b>	<b>Remark</b>	<b>Sign</b>
	14-08-2021 05:31:14	MayurYadav	Completed	old fire panel from 3rd floor remove with all accessories and install at 2nd floor new fire panel install at 3rd floor and programming done battery missing fault and detector fault for device above ceiling keys handover to patil sir	
	14-08-2021 10:11:45	MayurYadav	New		-
	14-08-2021 10:11:01	MayurYadav	New		-

Previous Complain History :			
	<b>Date Time</b>	<b>Technician Name</b>	<b>Remark</b>
	03-08-2023 10:55:52	Atique Salmani	11 dome 6 fish eye with pole bracket total cameras 17 3rd and 5th boath 6 Poe swich 3nos on third and 3 nos on 5th 32 channel NVR cable approx 550 meter And patil sir required old NVR 3 floor camera in 1 NVR and 5 th floor in 1 NVR
	29-07-2023 02:21:56	Ravi Rajbhar	1- 3rd floor main enterance biometric access divice scaner check our side ok working done but nandu sir they said sometimes it doesn't work divice 2- 5th floor it room sarver room em lock issue resloved only mainget paty propely fiting our side