







Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE7059																														
Priority :	Low																													
Created By :	Admin - Apurva Vajaria																													
Complaint Mob. No. :	9223207875																													
Technician Name :	Mayur Yadav		Technician Mobile :	8411951301																										
Ticket Type :	Complain	Date & Time :	10-12-2022 10:57:49																											
Vendor Details :																														
Company Name/Client Name :	Shoppers Stop Ltd - HO	Customer's Mobile :	9223207875	Name :	Nandu Sir																									
Address :																														
Mumbai , , , , Maharashtra																														
AMC Details :																														
Expiry Date :	01-01-1970 05:30:00		Type :																											
Product Name :	Fire																													
Complain :	smoke detector installation with base - 18 nos and 4 nos - backup battery installation																													
Technician Comment :	2 smoke detector install with base open loop problem in 3rd floor panel solve earth fault remove from third floor panel																													
Complain Operator :	Desktop - Apurva Vajaria																													
Remark :	2 smoke detector install with base open loop problem in 3rd floor panel solve earth fault remove from third floor panel																													
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>17-12-2022 06:08:25</td><td>MayurYadav</td><td>Completed</td><td>2 smoke detector install with base open loop problem in 3rd floor panel solve earth fault remove from third floor panel</td><td></td></tr><tr><td>17-12-2022 11:50:10</td><td>MayurYadav</td><td>New</td><td></td><td>-</td></tr><tr><td>10-12-2022 07:57:09</td><td>MayurYadav</td><td>Work Pending</td><td>4 nos backup battery install in 3rd and 5th floor panel 5th floor 8detector install (L1-63,55,53,23,20,18,51,26) 3rd floor 8detector install (L1-1,2/L2-80,82,77,95,53,54) 2 detector pending and earth fault in panel material handover to security</td><td></td></tr><tr><td>10-12-2022 10:58:39</td><td>MayurYadav</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	17-12-2022 06:08:25	MayurYadav	Completed	2 smoke detector install with base open loop problem in 3rd floor panel solve earth fault remove from third floor panel		17-12-2022 11:50:10	MayurYadav	New		-	10-12-2022 07:57:09	MayurYadav	Work Pending	4 nos backup battery install in 3rd and 5th floor panel 5th floor 8detector install (L1-63,55,53,23,20,18,51,26) 3rd floor 8detector install (L1-1,2/L2-80,82,77,95,53,54) 2 detector pending and earth fault in panel material handover to security		10-12-2022 10:58:39	MayurYadav	New		-
Date Time	Technician Name	Status	Remark	Sign																										
17-12-2022 06:08:25	MayurYadav	Completed	2 smoke detector install with base open loop problem in 3rd floor panel solve earth fault remove from third floor panel																											
17-12-2022 11:50:10	MayurYadav	New		-																										
10-12-2022 07:57:09	MayurYadav	Work Pending	4 nos backup battery install in 3rd and 5th floor panel 5th floor 8detector install (L1-63,55,53,23,20,18,51,26) 3rd floor 8detector install (L1-1,2/L2-80,82,77,95,53,54) 2 detector pending and earth fault in panel material handover to security																											
10-12-2022 10:58:39	MayurYadav	New		-																										

Previous Complain History :	Date Time	Technician Name	Remark
	16-12-2022 10:05:15	Ravi Rajbhar	recoding issue resolved date and time issue then time and date setting
	10-12-2022 11:34:07	MayurYadav	