




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE8602																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9223207875																			
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																
Ticket Type :	AMC visiting	Date & Time :	17-06-2023 11:01:54																	
Vendor Details :																				
Company Name/Client Name :	Shoppers Stop Ltd - HO	Customer's Mobile :	9223207875	Name :	Nandu Sir															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Ppm																			
Complain :	Fire PPM Need to do																			
Technician Comment :	ppm done of fire alarm ? 3rd floor 3 rd floor all smoke detectors clean and one smoke detectors no. 53 double show in panal old tailor room then need to change number smoke detectors 94 old tailor room battery fault show - battery missing loop 1 - total divice 91 loop 2 - total divice 78 5th floor 5th floor all smoke detectors clean and ok working done loop 1 - divice 93 loop 2- divice 73 fault show in panal battery waring both panal password -9898																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	ppm done of fire alarm ? 3rd floor 3 rd floor all smoke detectors clean and one smoke detectors no. 53 double show in panal old tailor room then need to change number smoke detectors 94 old tailor room battery fault show - battery missing loop 1 - total divice 91 loop 2 - total divice 78 5th floor 5th floor all smoke detectors clean and ok working done loop 1 - divice 93 loop 2- divice 73 fault show in panal battery waring both panal password -9898																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>17-06-2023 05:57:29</td><td>Ravi Rajbhar</td><td>Completed</td><td>ppm done of fire alarm ? 3rd floor 3 rd floor all smoke detectors clean and one smoke detectors no. 53 double show in panal old tailor room then need to change number smoke detectors 94 old tailor room battery fault show - battery missing loop 1 - total divice 91 loop 2 - total divice 78 5th floor 5th floor all smoke detectors clean and ok working done loop 1 - divice 93 loop 2- divice 73 fault show in panal battery waring both panal password -9898</td><td></td></tr><tr><td>17-06-2023 11:02:23</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	17-06-2023 05:57:29	Ravi Rajbhar	Completed	ppm done of fire alarm ? 3rd floor 3 rd floor all smoke detectors clean and one smoke detectors no. 53 double show in panal old tailor room then need to change number smoke detectors 94 old tailor room battery fault show - battery missing loop 1 - total divice 91 loop 2 - total divice 78 5th floor 5th floor all smoke detectors clean and ok working done loop 1 - divice 93 loop 2- divice 73 fault show in panal battery waring both panal password -9898		17-06-2023 11:02:23	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																
17-06-2023 05:57:29	Ravi Rajbhar	Completed	ppm done of fire alarm ? 3rd floor 3 rd floor all smoke detectors clean and one smoke detectors no. 53 double show in panal old tailor room then need to change number smoke detectors 94 old tailor room battery fault show - battery missing loop 1 - total divice 91 loop 2 - total divice 78 5th floor 5th floor all smoke detectors clean and ok working done loop 1 - divice 93 loop 2- divice 73 fault show in panal battery waring both panal password -9898																	
17-06-2023 11:02:23	Ravi Rajbhar	New		-																

Previous Complain History :			
	Date Time	Technician Name	Remark
	17-06-2023 10:21:15	Ravi Rajbhar	
	05-06-2023 12:25:56	Atique Salmani	3rd floor reception 2camera Non app room Private brand Tailor room cadd room There issue from NVR end eswich ulink cable rj 45 issue so recrimp from NVR ends working ok all cameras