Vallabh Enterprises

 $\label{eq:Regd.office:401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067 \\ \text{Support:} \mid \textbf{W}: www.vallabhenterprises.com \\ \textbf{E}: vallabhsecure@yahoo.co.in \\ \end{cases}$

Service Status De	tails: VE16012								
Priority:	Low	Low							
Created By:	Admin - Apurva Vajaria								
Complaint Mob.	9821036391								
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965					
Ticket Type :	Complain	Date & Time :	14-10-2025 11:23:09	-2025 11:23:09					
Vendor Details :									
Company Name/Client Name :	Petit Tower CHS Ltd	Customer's Mobile :	9821036391	Name :	Naozer Baldawala				
Address:									
Mumbai , , , , Ma	harashtra								
AMC Details :									
Expiry Date :	01-01-1970 05:30:00		Type:						
Product Name:	Intercom								
Complain:	Office intercom and main gate and lift intercom not working								
Technician Comment :	Sarvice lift intercom issue resolved but instument need to change because instument damege And members lift intercom issue resolved with main gate								
Complain Operator :	Desktop - Apurva Vajaria								
Remark:	Sarvice lift intercom issue resolved but instument need to change because instument damege And members lift intercom issue resolved with main gate								

Status History :	Date Time	Technician	Status	Remark	Sign
	Dute Time	Name	Status	Remark	Sign
	24-10-2025 05:03:12	Ravi Rajbhar	Completed	Sarvice lift intercom issue resolved but instument need to change because instument damege And members lift intercom issue resolved with main gate	Kawath
	24-10-2025 05:03:11	Ravi Rajbhar	Completed	Sarvice lift intercom issue resolved but instument need to change because instument damege And members lift intercom issue resolved with main gate	12mil and
	24-10-2025 12:56:47	Ravi Rajbhar	New		-
	17-10-2025 12:42:26	Ravi Rajbhar	New		-
	14-10-2025 11:35:52	Ravi Rajbhar	Work Pending	2 life & 1 gate intercom no ring problem & 1office phone not on	Moder
	14-10-2025 11:23:22	Ravi Rajbhar	New		-
Previous Complain History :	Date Time	Date Time Technician Name Remark			
	01-11-2025 11:32:40	TauseephRaza	PPM complete recording show 12floor poe switch issue 59 Camera working		
	25-10-2025 10:20:41	Ravi Rajbhar	12 floor poe switch issue need to change because poe switch faulty inform to security parson		