

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE11025																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9702786668																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	AMC visiting	Date & Time :	05-03-2024 12:59:38																	
Vendor Details :																				
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's Mobile :	9702786668	Name :	Nazia															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	30-09-2020 12:00:00		Type :	Comprehensive																
Product Name :	Ppm																			
Complain :	CCTV / Access / TA / Fire PPM need to do																			
Technician Comment :	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>05-03-2024 04:47:28</td><td>Atique Salmani</td><td>Completed</td><td>Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .</td><td></td></tr><tr><td>05-03-2024 12:59:45</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	05-03-2024 04:47:28	Atique Salmani	Completed	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .		05-03-2024 12:59:45	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
05-03-2024 04:47:28	Atique Salmani	Completed	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .																	
05-03-2024 12:59:45	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>01-02-2024 02:13:53</td><td>Atique Salmani</td><td>Hikvision and unv online in cell phone and pc also but mandir office dahua dvr offline becz data cat6 cable cut buy mouse so need to new cabling 60/70 metr .</td></tr><tr><td>24-11-2023 01:55:46</td><td>Shiva Meena</td><td>Software wark complete and online done</td></tr></tbody></table>					Date Time	Technician Name	Remark	01-02-2024 02:13:53	Atique Salmani	Hikvision and unv online in cell phone and pc also but mandir office dahua dvr offline becz data cat6 cable cut buy mouse so need to new cabling 60/70 metr .	24-11-2023 01:55:46	Shiva Meena	Software wark complete and online done						
Date Time	Technician Name	Remark																		
01-02-2024 02:13:53	Atique Salmani	Hikvision and unv online in cell phone and pc also but mandir office dahua dvr offline becz data cat6 cable cut buy mouse so need to new cabling 60/70 metr .																		
24-11-2023 01:55:46	Shiva Meena	Software wark complete and online done																		