

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE11370																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9702786668																			
Technician Name :	Siddhesh Chavan		Technician Mobile :	8080922985																
Ticket Type :	Complain	Date & Time :	12-04-2024 02:54:33																	
Vendor Details :																				
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's Mobile :	9702786668	Name :	Nazia															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	30-09-2020 12:00:00		Type :	Comprehensive																
Product Name :	CCTV																			
Complain :	online issue need to check																			
Technician Comment :	online working ok in mobile phones																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	online working ok in mobile phones																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>16-04-2024 12:11:50</td><td>Siddhesh Chavan</td><td>Completed</td><td>online working ok in mobile phones</td><td></td></tr><tr><td>16-04-2024 10:50:18</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	16-04-2024 12:11:50	Siddhesh Chavan	Completed	online working ok in mobile phones		16-04-2024 10:50:18	Siddhesh Chavan	New		-
Date Time	Technician Name	Status	Remark	Sign																
16-04-2024 12:11:50	Siddhesh Chavan	Completed	online working ok in mobile phones																	
16-04-2024 10:50:18	Siddhesh Chavan	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>05-03-2024 12:59:38</td><td>Atique Salmani</td><td>Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .</td></tr><tr><td>01-02-2024 02:13:53</td><td>Atique Salmani</td><td>Hikvision and unv online in cell phone and pc also but mandir office dahua dvr offline becz data cat6 cable cut buy mouse so need to new cabling 60/70 metr .</td></tr></tbody></table>					Date Time	Technician Name	Remark	05-03-2024 12:59:38	Atique Salmani	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .	01-02-2024 02:13:53	Atique Salmani	Hikvision and unv online in cell phone and pc also but mandir office dahua dvr offline becz data cat6 cable cut buy mouse so need to new cabling 60/70 metr .						
Date Time	Technician Name	Remark																		
05-03-2024 12:59:38	Atique Salmani	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .																		
01-02-2024 02:13:53	Atique Salmani	Hikvision and unv online in cell phone and pc also but mandir office dahua dvr offline becz data cat6 cable cut buy mouse so need to new cabling 60/70 metr .																		