




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

| Service Status Details : VE11776 | | | | | | | | | | | | | | | | | | | | | | | | | |
|---|--|--|--|---|-------|-----------|-----------------|--------|---------------------|----------------|--|---------------------|----------------|--|---|---------------------|----------------|-----|--|---|---------------------|----------------|-----|--|---|
| Priority : | Low | | | | | | | | | | | | | | | | | | | | | | | | |
| Created By : | Admin - Apurva Vajaria | | | | | | | | | | | | | | | | | | | | | | | | |
| Complaint Mob. No. : | 9702786668 | | | | | | | | | | | | | | | | | | | | | | | | |
| Technician Name : | Atique Salmani | | Technician Mobile : | 8080922984 | | | | | | | | | | | | | | | | | | | | | |
| Ticket Type : | Complain | Date & Time : | 30-05-2024 04:37:59 | | | | | | | | | | | | | | | | | | | | | | |
| Vendor Details : | | | | | | | | | | | | | | | | | | | | | | | | | |
| Company Name/Client Name : | Beam Hospital (Womens Hospital) | Customer's Mobile : | 9702786668 | Name : | Nazia | | | | | | | | | | | | | | | | | | | | |
| Address : | | | | | | | | | | | | | | | | | | | | | | | | | |
| Mumbai , , , , Maharashtra | | | | | | | | | | | | | | | | | | | | | | | | | |
| AMC Details : | | | | | | | | | | | | | | | | | | | | | | | | | |
| Expiry Date : | 30-09-2020 12:00:00 | | Type : | Comprehensive | | | | | | | | | | | | | | | | | | | | | |
| Product Name : | CCTV | | | | | | | | | | | | | | | | | | | | | | | | |
| Complain : | 3rd floor DVR offline Lan cabling done by electrician need to do online the same | | | | | | | | | | | | | | | | | | | | | | | | |
| Technician Comment : | 3rd floor dahua dvr I line done with crimping working ok And mrd room camera installation done working ok. | | | | | | | | | | | | | | | | | | | | | | | | |
| Complain Operator : | Desktop - Apurva Vajaria | | | | | | | | | | | | | | | | | | | | | | | | |
| Remark : | 3rd floor dahua dvr I line done with crimping working ok And mrd room camera installation done working ok. | | | | | | | | | | | | | | | | | | | | | | | | |
| Status History : | <table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>10-06-2024 03:45:30</td><td>Atique Salmani</td><td>Completed</td><td>3rd floor dahua dvr I line done with crimping working ok And mrd room camera installation done working ok.</td><td></td></tr><tr><td>10-06-2024 11:12:39</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>30-05-2024 04:38:07</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table> | | | | | Date Time | Technician Name | Status | Remark | Sign | 10-06-2024 03:45:30 | Atique Salmani | Completed | 3rd floor dahua dvr I line done with crimping working ok And mrd room camera installation done working ok. |  | 10-06-2024 11:12:39 | Atique Salmani | New | | - | 30-05-2024 04:38:07 | Atique Salmani | New | | - |
| Date Time | Technician Name | Status | Remark | Sign | | | | | | | | | | | | | | | | | | | | | |
| 10-06-2024 03:45:30 | Atique Salmani | Completed | 3rd floor dahua dvr I line done with crimping working ok And mrd room camera installation done working ok. |  | | | | | | | | | | | | | | | | | | | | | |
| 10-06-2024 11:12:39 | Atique Salmani | New | | - | | | | | | | | | | | | | | | | | | | | | |
| 30-05-2024 04:38:07 | Atique Salmani | New | | - | | | | | | | | | | | | | | | | | | | | | |
| Previous Complain History : | <table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>19-06-2024 02:42:46</td><td>Atique Salmani</td><td>Mrd room new smoke detectors changed with base working ok. And online issue resolved ther is changed static IP so report forwarding on mercusur router working ok.</td></tr><tr><td>30-05-2024 10:49:23</td><td>Atique Salmani</td><td>Ppm completed and 3 floor mandi dahua dvr offline becz lan cable cut by mouse new cabling going on and mrd room smoke detector and camera collect becz faulty.</td></tr></tbody></table> | | | | | Date Time | Technician Name | Remark | 19-06-2024 02:42:46 | Atique Salmani | Mrd room new smoke detectors changed with base working ok. And online issue resolved ther is changed static IP so report forwarding on mercusur router working ok. | 30-05-2024 10:49:23 | Atique Salmani | Ppm completed and 3 floor mandi dahua dvr offline becz lan cable cut by mouse new cabling going on and mrd room smoke detector and camera collect becz faulty. | | | | | | | | | | | |
| Date Time | Technician Name | Remark | | | | | | | | | | | | | | | | | | | | | | | |
| 19-06-2024 02:42:46 | Atique Salmani | Mrd room new smoke detectors changed with base working ok. And online issue resolved ther is changed static IP so report forwarding on mercusur router working ok. | | | | | | | | | | | | | | | | | | | | | | | |
| 30-05-2024 10:49:23 | Atique Salmani | Ppm completed and 3 floor mandi dahua dvr offline becz lan cable cut by mouse new cabling going on and mrd room smoke detector and camera collect becz faulty. | | | | | | | | | | | | | | | | | | | | | | | |