Vallabh Enterprises

 $\label{eq:Regd.office:401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067 \\ \text{Support:} \mid \textbf{W}: www.vallabhenterprises.com \\ \textbf{E}: vallabhsecure@yahoo.co.in \\ \end{cases}$

Service Status D	etails : VE13401						
Priority:	Low						
Created By:	Admin - Apurva Vajaria						
Complaint Mob. No. :	9702786668						
Technician Name :	Atique Salmani		Т	echnician Mobile :	8080922984		
Ticket Type :	AMC visiting	Date & Tim	e : 2	8-11-2024 03:01:39			
Vendor Details :							
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's M	Mobile : 9	702786668	Name :	Nazia	
Address :			-				
Mumbai , , , , M	aharashtra						
AMC Details:							
Expiry Date :	30-09-2020 12:00:00			ype:	Comprehensive)	
Product Name:	Ppm						
Complain:	Smoke detector issue and CCTV / TA Access / PA /FAS PPM need to do						
Technician Comment :	Ppm done all working ok 2nd floor passage camera no vedeo issues resolved Biomatric boath side crimping done and data ganrate working ok time attendance issue resolved Fire pannel working ok but in display digit not showing All 3 dvr make cheknlost and mandir dvr dat n time reset and 2 cameras off issue resolved G.L.D. smps was off someone removed plug so plug in and working also shown to gazala mam						
Complain Operator :	Desktop - Apurva Vajaria						
Remark :	Ppm done all working ok 2nd floor passage camera no vedeo issues resolved Biomatric boath side crimping done and data ganrate working ok time attendance issue resolved Fire pannel working ok but in display digit not showing All 3 dvr make cheknlost and mandir dvr dat n time reset and 2 cameras off issue resolved G.L.D. smps was off someone removed plug so plug in and working also shown to gazala mam						
Status History :	Date Time	Technician Name	Status	Rema	ark	Sign	
	30-11-2024 04:46:02	Atique Salmani	Completed	Ppm done all working ok 2nd floor passage camera no vedeo issues resolved Biomatric boath side crimping done and data ganrate working ok time attendance issue resolved Fire pannel working ok but in display digit not showing All 3 dvr make cheknlost and mandir dvr dat n time reset and 2 cameras off issue resolved G.L.D. smps was off someone removed plug so plug in and working also shown to gazala mam		AD	
	28-11-2024 06:42:24	Atique Salmani	New			-	

Previous	S
Complai	in
History	:

Date Time	Technician Name	Remark	
04-11-2024 03:13:30	Atique Salmani	There is static ip was Expired so it was offline so cordinate with internet provider and issue resolved working ok .	
15-10-2024 11:16:35	Atique Salmani	Dvr and nvr online done Nazia mam and gazala mam it's working ok and also Bindu mam ivms uninstall and install hikconnnet and online on static ip working ok	