




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE5649																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9702786668																								
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																					
Ticket Type :	Complain	Date & Time :	05-06-2022 04:11:07																						
Vendor Details :																									
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's Mobile :	9702786668	Name :	Nazia																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	30-09-2020 12:00:00		Type :	Comprehensive																					
Product Name :	Ppm																								
Complain :	Cctv																								
Technician Comment :	cctv ppm all camera check working ok fire ppm done all detector working ok MCP working and fire panel working ok																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	cctv ppm all camera check working ok fire ppm done all detector working ok MCP working and fire panel working ok																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>05-06-2022 04:23:33</td><td>Atique Salmani</td><td>Completed</td><td>cctv ppm all camera check working ok fire ppm done all detector working ok MCP working and fire panel working ok</td><td></td></tr><tr><td>05-06-2022 04:11:27</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>05-06-2022 04:11:07</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	05-06-2022 04:23:33	Atique Salmani	Completed	cctv ppm all camera check working ok fire ppm done all detector working ok MCP working and fire panel working ok		05-06-2022 04:11:27	Atique Salmani	New		-	05-06-2022 04:11:07	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																					
05-06-2022 04:23:33	Atique Salmani	Completed	cctv ppm all camera check working ok fire ppm done all detector working ok MCP working and fire panel working ok																						
05-06-2022 04:11:27	Atique Salmani	New		-																					
05-06-2022 04:11:07	Atique Salmani	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>28-04-2022 10:54:52</td><td>Atique Salmani</td><td>2 cameras reconnection main gate and store room main n gate bnc changed and store room recoction but issue not resolved need check dvr ends and reception camera also need to check o.t . camera need to changed work painding .</td></tr><tr><td>06-04-2022 10:51:35</td><td>Atique Salmani</td><td>one dome camera o.t. changed old camera hand over to client and working ok.</td></tr></tbody></table>					Date Time	Technician Name	Remark	28-04-2022 10:54:52	Atique Salmani	2 cameras reconnection main gate and store room main n gate bnc changed and store room recoction but issue not resolved need check dvr ends and reception camera also need to check o.t . camera need to changed work painding .	06-04-2022 10:51:35	Atique Salmani	one dome camera o.t. changed old camera hand over to client and working ok.											
Date Time	Technician Name	Remark																							
28-04-2022 10:54:52	Atique Salmani	2 cameras reconnection main gate and store room main n gate bnc changed and store room recoction but issue not resolved need check dvr ends and reception camera also need to check o.t . camera need to changed work painding .																							
06-04-2022 10:51:35	Atique Salmani	one dome camera o.t. changed old camera hand over to client and working ok.																							