

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE5670																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9702786668																								
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																					
Ticket Type :	New Installation	Date & Time :	09-06-2022 12:14:15																						
Vendor Details :																									
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's Mobile :	9702786668	Name :	Nazia																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	30-09-2020 12:00:00		Type :	Comprehensive																					
Product Name :	Time And Attendance																								
Complain :	New biometric installation																								
Technician Comment :	installation of biometric device done and make 3 admin Sangeeta mam nazia mam and vallabh 3107 3107 in lan attendance need tonlay cable approx 25to 30 and add employees 8/9 .																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	installation of biometric device done and make 3 admin Sangeeta mam nazia mam and vallabh 3107 3107 in lan attendance need tonlay cable approx 25to 30 and add employees 8/9 .																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>09-06-2022 03:22:58</td><td>Atique Salmani</td><td>Completed</td><td>installation of biometric device done and make 3 admin Sangeeta mam nazia mam and vallabh 3107 3107 in lan attendance need tonlay cable approx 25to 30 and add employees 8/9 .</td><td></td></tr><tr><td>09-06-2022 12:14:34</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>09-06-2022 12:14:15</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	09-06-2022 03:22:58	Atique Salmani	Completed	installation of biometric device done and make 3 admin Sangeeta mam nazia mam and vallabh 3107 3107 in lan attendance need tonlay cable approx 25to 30 and add employees 8/9 .		09-06-2022 12:14:34	Atique Salmani	New		-	09-06-2022 12:14:15	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																					
09-06-2022 03:22:58	Atique Salmani	Completed	installation of biometric device done and make 3 admin Sangeeta mam nazia mam and vallabh 3107 3107 in lan attendance need tonlay cable approx 25to 30 and add employees 8/9 .																						
09-06-2022 12:14:34	Atique Salmani	New		-																					
09-06-2022 12:14:15	Atique Salmani	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>05-06-2022 04:11:07</td><td>Atique Salmani</td><td>cctv ppm all camera check working ok fire ppm done all detector working ok MCP working and fire panel working ok</td></tr><tr><td>28-04-2022 10:54:52</td><td>Atique Salmani</td><td>2 cameras reconnection main gate and store room main n gate bnc changed and store room recoction but issue not resolved need check dvr ends and reception camera also need to check o.t . camera need to changed work painting .</td></tr></tbody></table>					Date Time	Technician Name	Remark	05-06-2022 04:11:07	Atique Salmani	cctv ppm all camera check working ok fire ppm done all detector working ok MCP working and fire panel working ok	28-04-2022 10:54:52	Atique Salmani	2 cameras reconnection main gate and store room main n gate bnc changed and store room recoction but issue not resolved need check dvr ends and reception camera also need to check o.t . camera need to changed work painting .											
Date Time	Technician Name	Remark																							
05-06-2022 04:11:07	Atique Salmani	cctv ppm all camera check working ok fire ppm done all detector working ok MCP working and fire panel working ok																							
28-04-2022 10:54:52	Atique Salmani	2 cameras reconnection main gate and store room main n gate bnc changed and store room recoction but issue not resolved need check dvr ends and reception camera also need to check o.t . camera need to changed work painting .																							