




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE6772																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9702786668																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	AMC visiting	Date & Time :	05-11-2022 06:44:17																	
Vendor Details :																				
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's Mobile :	9702786668	Name :	Nazia															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	30-09-2020 12:00:00		Type :	Comprehensive																
Product Name :	Ppm																			
Complain :	CCTV / Access / TA / Fire																			
Technician Comment :	ppm done check fire alarm pannel and cleaned smoke detector and cameras panel working on healthy condition also check by mcp fire and attendance report working ok access make report of all things .and one main gate camera angel settings done.																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	ppm done check fire alarm pannel and cleaned smoke detector and cameras panel working on healthy condition also check by mcp fire and attendance report working ok access make report of all things .and one main gate camera angel settings done.																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>06-11-2022 04:06:55</td><td>Atique Salmani</td><td>Completed</td><td>ppm done check fire alarm pannel and cleaned smoke detector and cameras panel working on healthy condition also check by mcp fire and attendance report working ok access make report of all things .and one main gate camera angel settings done.</td><td></td></tr><tr><td>05-11-2022 06:44:24</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	06-11-2022 04:06:55	Atique Salmani	Completed	ppm done check fire alarm pannel and cleaned smoke detector and cameras panel working on healthy condition also check by mcp fire and attendance report working ok access make report of all things .and one main gate camera angel settings done.		05-11-2022 06:44:24	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
06-11-2022 04:06:55	Atique Salmani	Completed	ppm done check fire alarm pannel and cleaned smoke detector and cameras panel working on healthy condition also check by mcp fire and attendance report working ok access make report of all things .and one main gate camera angel settings done.																	
05-11-2022 06:44:24	Atique Salmani	New		-																

Previous Complain History :			
	Date Time	Technician Name	Remark
	20-10-2022 10:58:35	Prashant Nikalje	dvr online on static ip with port forwarding ivms desktop and ivms mobile app configuration done given training to leena madam how to generate monthly details reports
	01-09-2022 10:21:18	Atique Salmani	we checked fire panell and test 15 to 20 mnts all zones healthy there is some wooden wooden work so it was hootring so need to ppm of fire by blower all sensors need to clean day n time confirm will be Nazia mam.