




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE7905																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9702786668																								
Technician Name :	Siddhesh Chavan		Technician Mobile :	8080922985																					
Ticket Type :	AMC visiting	Date & Time :	18-03-2023 10:37:40																						
Vendor Details :																									
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's Mobile :	9702786668	Name :	Nazia																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	30-09-2020 12:00:00		Type :	Comprehensive																					
Product Name :	Ppm																								
Complain :	CCTV / Access / TA / Fire need to do ppm																								
Technician Comment :	ppm pending because 3rd floor somke sensor need to do install remove I client and 3rd floor CCTV system remove by client need to do install																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	ppm pending because 3rd floor somke sensor need to do install remove I client and 3rd floor CCTV system remove by client need to do install																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>18-03-2023 05:59:22</td><td>Siddhesh Chavan</td><td>Work Pending</td><td>ppm pending because 3rd floor somke sensor need to do install remove I client and 3rd floor CCTV system remove by client need to do install</td><td></td></tr><tr><td>18-03-2023 02:33:55</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr><tr><td>18-03-2023 10:37:59</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	18-03-2023 05:59:22	Siddhesh Chavan	Work Pending	ppm pending because 3rd floor somke sensor need to do install remove I client and 3rd floor CCTV system remove by client need to do install		18-03-2023 02:33:55	Siddhesh Chavan	New		-	18-03-2023 10:37:59	Siddhesh Chavan	New		-
Date Time	Technician Name	Status	Remark	Sign																					
18-03-2023 05:59:22	Siddhesh Chavan	Work Pending	ppm pending because 3rd floor somke sensor need to do install remove I client and 3rd floor CCTV system remove by client need to do install																						
18-03-2023 02:33:55	Siddhesh Chavan	New		-																					
18-03-2023 10:37:59	Siddhesh Chavan	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>15-07-2023 10:32:24</td><td>Atique Salmani</td><td>In Manju mam phone cctv online done working ok.</td></tr><tr><td>23-06-2023 10:31:29</td><td>Atique Salmani</td><td>All smok detector checked working ok also check by mcps and o.t. door access issue resolved 3rd floor 3 camera issue resolved and one smoke detector by pass by our engineer so it's need to fix in boss office in next visit boss meeting going on so painting.</td></tr></tbody></table>					Date Time	Technician Name	Remark	15-07-2023 10:32:24	Atique Salmani	In Manju mam phone cctv online done working ok.	23-06-2023 10:31:29	Atique Salmani	All smok detector checked working ok also check by mcps and o.t. door access issue resolved 3rd floor 3 camera issue resolved and one smoke detector by pass by our engineer so it's need to fix in boss office in next visit boss meeting going on so painting.											
Date Time	Technician Name	Remark																							
15-07-2023 10:32:24	Atique Salmani	In Manju mam phone cctv online done working ok.																							
23-06-2023 10:31:29	Atique Salmani	All smok detector checked working ok also check by mcps and o.t. door access issue resolved 3rd floor 3 camera issue resolved and one smoke detector by pass by our engineer so it's need to fix in boss office in next visit boss meeting going on so painting.																							