



Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | **W :** www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE9929					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9702786668				
Technician Name :	Atique Salmani		Technician Mobile :	8080922984	
Ticket Type :	AMC visiting	Date & Time :	28-10-2023 12:10:47		
Vendor Details :					
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's Mobile :	9702786668	Name :	Nazia
Address :					
Mumbai , , , , Maharashtra					
AMC Details :					
Expiry Date :	30-09-2020 12:00:00		Type :	Comprehensive	
Product Name :	Ppm				
Complain :	CCTV/Access/TA/Fire - PPM Need to do				
Technician Comment :	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .biomax time attendance painding becz network raged changed . Need to visit when net person available. Also in NVR all cameras naming done according to supr visor .				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .biomax time attendance painding becz network raged changed . Need to visit when net person available. Also in NVR all cameras naming done according to supr visor .				

Status History :

Date Time	Technician Name	Status	Remark	Sign
05-03-2024 04:51:28	Atique Salmani	Completed	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .biomax time attendance paining becز network raged changed . Need to visit when net person available. Also in NVR all cameras naming done according to supr visor .	
05-03-2024 12:58:17	Atique Salmani	Work Pending		-
05-03-2024 12:58:14	Atique Salmani	Completed		-
30-10-2023 11:55:54	Atique Salmani	Work Pending		-
28-10-2023 04:38:30	Atique Salmani	Completed	Cctv fire and access pp. Done and in dvr 11 nmbr camera was blurr so changed BNC dc and ok and fire paneel check by smoke it's working ok but in pannel on display not showing digit.	
28-10-2023 12:10:56	Atique Salmani	New		-

Previous Complain History :

Date Time	Technician Name	Remark
05-03-2024 12:59:38	Atique Salmani	Cctv fire access ppm done all working ok chek all detector and mcp manaaul call and checked .
01-02-2024 02:13:53	Atique Salmani	Hikvision and unv online in cell phone and pc also but mandir office dahua dvr offline becز data cat6 cable cut buy mouse so need to new cabling 60/70 metr .