Vallabh Enterprises

 $\label{eq:Regd.office:401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067 \\ \text{Support:} \mid \textbf{W}: www.vallabhenterprises.com \\ \textbf{E}: vallabhsecure@yahoo.co.in \\ \end{cases}$

Service Status Details : VE4114						
Priority:	Low					
Created By:	Admin - Apurva Vajaria					
Complaint Mob. No. :	9967522687					
Technician Name	Siddhesh Chavan		Technician :	Mobile	8080922985	
Ticket Type :	Complain	Date & Time :	26-10-2021 10:29:08			
Vendor Details :						
Company Name/Client Name :	Damji Shamji - Tivon Park G&H Wing	Customer's Mobile :	9967522687		Name :	Nilesh Mane Sir
Address:						
Mumbai , , , 400086 , Maharashtra						
AMC Details :						
Expiry Date :	01-01-1970 05:30:00		Type:			
Product Name :	Intercom					
Complain:	intercom issue					
Technician Comment :	H wing 504 intercom issue resolved G wing 302 working ok 402 intercom issue resolved 803 cable cut intercom system to floor duck					
Complain Operator :	Desktop - Apurva Vajaria					
Remark:	H wing 504 intercom issue resolved G wing 302 working ok 402 intercom issue resolved 803 cable cut intercom system to floor duck $^{\circ}$					
Status History :	Date Time	Technician Name	Status	Remark H wing 504 intercom issue resolved G wing 302 working ok 402 intercom issue resolved 803 cable cut intercom system to floor duck		Sign
	26-10-2021 01:36:49	Siddhesh Chavan	Completed			A S
	26-10-2021 10:29:27	Siddhesh Chavan	New			-
	26-10-2021 10:29:08	Siddhesh Chavan	New			-
Previous Complain History :	Date Time	Technician Name	Remark			
	13-02-2022 12:33:35	YogeshDesai				
	12-02-2022 06:57:13	YogeshDesai	intercom system two pin was burnt . new two pin has been installed all line working ok flat no 302, 502 , 602 . all completed. $ \frac{1}{2} \left(\frac{1}{2} \right) = \frac{1}{2} \left(\frac{1}{2} \right) \left(\frac{1}{$			