

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12349					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9004700906				
Technician Name :	Rahul Mhapralkar		Technician Mobile :	9168762949	
Ticket Type :	AMC visiting	Date & Time :	06-08-2024 11:26:21		
Vendor Details :					
Company Name/Client Name :	Value Beverage	Customer's Mobile :	9004700906	Name :	Poonam Madam
Address :					
Mumbai , , , 400710 , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Ppm				
Complain :	one access door not working and PPM need to do				
Technician Comment :	EML Lock power Supply issue resolved, this power Supply given by client. 2 floor EML lock Broken need to replace. PPM Done				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	EML Lock power Supply issue resolved, this power Supply given by client. 2 floor EML lock Broken need to replace. PPM Done				
Status History :	Date Time	Technician Name	Status	Remark	Sign
	23-08-2024 12:55:26	Rahul Mhapralkar	Completed		-
	06-08-2024 11:53:35	Rahul Mhapralkar	Work Pending	EML Lock power Supply issue resolved, this power Supply given by client. 2 floor EML lock Broken need to replace. PPM Done	
	06-08-2024 11:26:32	Rahul Mhapralkar	New		-
Previous Complain History :	Date Time	Technician Name	Remark		
	23-08-2024 12:55:58	Shiva Meena	Look install done work complete		
	29-06-2024 04:08:09	SantoshPathak			