




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE3770																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9004700906																								
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																					
Ticket Type :	Complain	Date & Time :	03-09-2021 10:12:33																						
Vendor Details :																									
Company Name/Client Name :	Value Beverage	Customer's Mobile :	9004700906	Name :	Poonam Madam																				
Address :																									
Mumbai , , , 400710 , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Access																								
Complain :	To realigned lock																								
Technician Comment :	access issue resolved and ok working done cable check system to door and recannetion with cable pair chenge alament issue resolved canfirm to client (Atur mentence parson) all ok working																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	access issue resolved and ok working done cable check system to door and recannetion with cable pair chenge alament issue resolved canfirm to client (Atur mentence parson) all ok working																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>03-09-2021 04:40:15</td><td>Ravi Rajbhar</td><td>Completed</td><td>access issue resolved and ok working done cable check system to door and recannetion with cable pair chenge alament issue resolved canfirm to client (Atur mentence parson) all ok working</td><td></td></tr><tr><td>03-09-2021 10:12:47</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>03-09-2021 10:12:33</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	03-09-2021 04:40:15	Ravi Rajbhar	Completed	access issue resolved and ok working done cable check system to door and recannetion with cable pair chenge alament issue resolved canfirm to client (Atur mentence parson) all ok working		03-09-2021 10:12:47	Ravi Rajbhar	New		-	03-09-2021 10:12:33	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
03-09-2021 04:40:15	Ravi Rajbhar	Completed	access issue resolved and ok working done cable check system to door and recannetion with cable pair chenge alament issue resolved canfirm to client (Atur mentence parson) all ok working																						
03-09-2021 10:12:47	Ravi Rajbhar	New		-																					
03-09-2021 10:12:33	Ravi Rajbhar	New		-																					

Previous Complain History :			
	Date Time	Technician Name	Remark
	10-07-2023 10:28:43	Atique Salmani	Basement lock was moving so remooved totally and reinstalled proper And also reconnection from pannel working ok and on under observation and 1 St floor lock faulty need to changed em lock And 3 floor toilet side lock alliingment done and magnet fixed proper . Also checked production room door lock .
	13-06-2023 10:53:23	MayurYadav	Ground floor Access door push button cable one pair not working Pair change door working ok open with push button