

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE3981																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9004700906																			
Technician Name :	Yogesh Desai	Technician Mobile :	8080922963																	
Ticket Type :	New Installation	Date & Time :	06-10-2021 10:07:33																	
Vendor Details :																				
Company Name/Client Name :	Value Beverage	Customer's Mobile :	9004700906	Name :	Poonam Madam															
Address :																				
Mumbai , , , 400710 , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Access																			
Complain :	deliver / add 20 cards																			
Technician Comment :																				
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :																				
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>06-10-2021 10:08:01</td><td>YogeshDesai</td><td>New</td><td></td><td>-</td></tr><tr><td>06-10-2021 10:07:33</td><td>YogeshDesai</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	06-10-2021 10:08:01	YogeshDesai	New		-	06-10-2021 10:07:33	YogeshDesai	New		-
Date Time	Technician Name	Status	Remark	Sign																
06-10-2021 10:08:01	YogeshDesai	New		-																
06-10-2021 10:07:33	YogeshDesai	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>10-07-2023 10:28:43</td><td>Atique Salmani</td><td>Basement lock was moving so remooved totally and reinstalled proper And also reconnection from pannel working ok and on under observation and 1 St floor lock faulty need to changed em lock And 3 floor toilet side lock allingment done and magnet fixed proper . Also checked production room door lock .</td></tr><tr><td>13-06-2023 10:53:23</td><td>MayurYadav</td><td>Ground floor Access door push button cable one pair not working Pair change door working ok open with push button</td></tr></tbody></table>					Date Time	Technician Name	Remark	10-07-2023 10:28:43	Atique Salmani	Basement lock was moving so remooved totally and reinstalled proper And also reconnection from pannel working ok and on under observation and 1 St floor lock faulty need to changed em lock And 3 floor toilet side lock allingment done and magnet fixed proper . Also checked production room door lock .	13-06-2023 10:53:23	MayurYadav	Ground floor Access door push button cable one pair not working Pair change door working ok open with push button						
Date Time	Technician Name	Remark																		
10-07-2023 10:28:43	Atique Salmani	Basement lock was moving so remooved totally and reinstalled proper And also reconnection from pannel working ok and on under observation and 1 St floor lock faulty need to changed em lock And 3 floor toilet side lock allingment done and magnet fixed proper . Also checked production room door lock .																		
13-06-2023 10:53:23	MayurYadav	Ground floor Access door push button cable one pair not working Pair change door working ok open with push button																		