




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE1266																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9987051684																								
Technician Name :	Sachin Pawar		Technician Mobile :	8080922981																					
Ticket Type :	Complain	Date & Time :	29-02-2020 02:06:56																						
Vendor Details :																									
Company Name/Client Name :	Nikhil Bobade	Customer's Mobile :	9987051684	Name :	Poonam																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	automation																								
Complain :	2 modules issue - its on Continuously also check all modules installed																								
Technician Comment :	one working module which is having only one connection is replaced with faulty (in that l1 and l2 is not working but l3 is working) now its working fine both module.																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	one working module which is having only one connection is replaced with faulty (in that l1 and l2 is not working but l3 is working) now its working fine both module.																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>04-03-2020 12:06:08</td><td>SachinPawar</td><td>Completed</td><td>one working module which is having only one connection is replaced with faulty (in that l1 and l2 is not working but l3 is working) now its working fine both module.</td><td></td></tr><tr><td>04-03-2020 10:16:29</td><td>SachinPawar</td><td>New</td><td></td><td>-</td></tr><tr><td>29-02-2020 02:06:57</td><td>SachinPawar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	04-03-2020 12:06:08	SachinPawar	Completed	one working module which is having only one connection is replaced with faulty (in that l1 and l2 is not working but l3 is working) now its working fine both module.		04-03-2020 10:16:29	SachinPawar	New		-	29-02-2020 02:06:57	SachinPawar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
04-03-2020 12:06:08	SachinPawar	Completed	one working module which is having only one connection is replaced with faulty (in that l1 and l2 is not working but l3 is working) now its working fine both module.																						
04-03-2020 10:16:29	SachinPawar	New		-																					
29-02-2020 02:06:57	SachinPawar	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>02-01-2020 10:03:55</td><td>Chandan Shiva</td><td>one hall module is faulty bring back to office</td></tr><tr><td>04-09-2019 04:57:40</td><td>SachinPawar</td><td>curton module is replecd with old one old one module line 3 not working.</td></tr></tbody></table>					Date Time	Technician Name	Remark	02-01-2020 10:03:55	Chandan Shiva	one hall module is faulty bring back to office	04-09-2019 04:57:40	SachinPawar	curton module is replecd with old one old one module line 3 not working.											
Date Time	Technician Name	Remark																							
02-01-2020 10:03:55	Chandan Shiva	one hall module is faulty bring back to office																							
04-09-2019 04:57:40	SachinPawar	curton module is replecd with old one old one module line 3 not working.																							