

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE4645																														
Priority :	Low																													
Created By :	Admin - Apurva Vajaria																													
Complaint Mob. No. :	9619151939																													
Technician Name :			Technician Mobile :																											
Ticket Type :	Complain	Date & Time :	24-01-2022 11:32:08																											
Vendor Details :																														
Company Name/Client Name :	Taj Hotel Santacruz	Customer's Mobile :	9619151939	Name :	Purnanand Petwal																									
Address :																														
Mumbai , Santacruz East, Mumbai, Maharashtra, India , , 400099 , Maharashtra																														
AMC Details :																														
Expiry Date :	01-01-1970 05:30:00		Type :																											
Product Name :	intrusion																													
Complain :	service of intrusion alarm system																													
Technician Comment :	352 mc. circuit replace but not on divice bcz no power 438 mc circuit reconnection ok working 344 mc circuit replace ok working 543 mc circuit reconnection ok working done all room are occupai																													
Complain Operator :	Desktop - Apurva Vajaria																													
Remark :	352 mc. circuit replace but not on divice bcz no power 438 mc circuit reconnection ok working 344 mc circuit replace ok working 543 mc circuit reconnection ok working done all room are occupai																													
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>08-02-2022 06:35:09</td><td></td><td>Work Pending</td><td>352 mc. circuit replace but not on divice bcz no power 438 mc circuit reconnection ok working 344 mc circuit replace ok working 543 mc circuit reconnection ok working done all room are occupai</td><td></td></tr><tr><td>08-02-2022 12:06:26</td><td></td><td>New</td><td></td><td>-</td></tr><tr><td>24-01-2022 11:32:49</td><td></td><td>New</td><td></td><td>-</td></tr><tr><td>24-01-2022 11:32:09</td><td></td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	08-02-2022 06:35:09		Work Pending	352 mc. circuit replace but not on divice bcz no power 438 mc circuit reconnection ok working 344 mc circuit replace ok working 543 mc circuit reconnection ok working done all room are occupai		08-02-2022 12:06:26		New		-	24-01-2022 11:32:49		New		-	24-01-2022 11:32:09		New		-
Date Time	Technician Name	Status	Remark	Sign																										
08-02-2022 06:35:09		Work Pending	352 mc. circuit replace but not on divice bcz no power 438 mc circuit reconnection ok working 344 mc circuit replace ok working 543 mc circuit reconnection ok working done all room are occupai																											
08-02-2022 12:06:26		New		-																										
24-01-2022 11:32:49		New		-																										
24-01-2022 11:32:09		New		-																										
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>13-06-2023 11:07:42</td><td>Ravi Rajbhar</td><td>437 need to change small cricit with magnetic contact 446 issue resloved 445 issue resloved</td></tr><tr><td>22-08-2022 01:13:19</td><td>Prashant Nikalje</td><td></td></tr></tbody></table>					Date Time	Technician Name	Remark	13-06-2023 11:07:42	Ravi Rajbhar	437 need to change small cricit with magnetic contact 446 issue resloved 445 issue resloved	22-08-2022 01:13:19	Prashant Nikalje																	
Date Time	Technician Name	Remark																												
13-06-2023 11:07:42	Ravi Rajbhar	437 need to change small cricit with magnetic contact 446 issue resloved 445 issue resloved																												
22-08-2022 01:13:19	Prashant Nikalje																													