




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE317																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	8660896542																								
Technician Name :	Anil Yadav		Technician Mobile :	8080922983																					
Ticket Type :	Complain	Date & Time :	11-09-2019 11:28:13																						
Vendor Details :																									
Company Name/Client Name :	Concentrix Services India Pvt Ltd - 4A	Customer's Mobile :	8660896542	Name :	Rahim																				
Address :																									
bangalore , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Ppm																								
Complain :	CCTV , Access, Intrusion and PBA																								
Technician Comment :	1. 7 controller cable dressing. 2. 3nd floor one camera blur issue and vpo 1 resolved. 3. ppm complete and all complaint solve.																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	1. 7 controller cable dressing. 2. 3nd floor one camera blur issue and vpo 1 resolved. 3. ppm complete and all complaint solve.																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>28-09-2019 03:07:02</td><td>AnilYadav</td><td>Completed</td><td>1. 7 controller cable dressing. 2. 3nd floor one camera blur issue and vpo 1 resolved. 3. ppm complete and all complaint solve.</td><td></td></tr><tr><td>20-09-2019 12:40:45</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr><tr><td>11-09-2019 11:28:13</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	28-09-2019 03:07:02	AnilYadav	Completed	1. 7 controller cable dressing. 2. 3nd floor one camera blur issue and vpo 1 resolved. 3. ppm complete and all complaint solve.		20-09-2019 12:40:45	AnilYadav	New		-	11-09-2019 11:28:13	AnilYadav	New		-
Date Time	Technician Name	Status	Remark	Sign																					
28-09-2019 03:07:02	AnilYadav	Completed	1. 7 controller cable dressing. 2. 3nd floor one camera blur issue and vpo 1 resolved. 3. ppm complete and all complaint solve.																						
20-09-2019 12:40:45	AnilYadav	New		-																					
11-09-2019 11:28:13	AnilYadav	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>03-10-2019 02:21:57</td><td>AnilYadav</td><td>All work completed NVR, panic baar, camera,two access door.</td></tr><tr><td>23-09-2019 01:56:29</td><td>AnilYadav</td><td>1. 4 ip camera installed. 2. one 64 ch NVR installed. 3. the em lock installed. 4. 3 multi glass reader installed. 5. one Dorma panic baar installed. 6. 3 magnetic contact installed. 7. one exit switch and two ers installed. 8. 8 core cabling completed 290 MTR. All new system working condition now handover completed.</td></tr></tbody></table>					Date Time	Technician Name	Remark	03-10-2019 02:21:57	AnilYadav	All work completed NVR, panic baar, camera,two access door.	23-09-2019 01:56:29	AnilYadav	1. 4 ip camera installed. 2. one 64 ch NVR installed. 3. the em lock installed. 4. 3 multi glass reader installed. 5. one Dorma panic baar installed. 6. 3 magnetic contact installed. 7. one exit switch and two ers installed. 8. 8 core cabling completed 290 MTR. All new system working condition now handover completed.											
Date Time	Technician Name	Remark																							
03-10-2019 02:21:57	AnilYadav	All work completed NVR, panic baar, camera,two access door.																							
23-09-2019 01:56:29	AnilYadav	1. 4 ip camera installed. 2. one 64 ch NVR installed. 3. the em lock installed. 4. 3 multi glass reader installed. 5. one Dorma panic baar installed. 6. 3 magnetic contact installed. 7. one exit switch and two ers installed. 8. 8 core cabling completed 290 MTR. All new system working condition now handover completed.																							