Vallabh Enterprises

 $\label{eq:Regd.office:401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067 \\ \text{Support:} \mid \textbf{W}: www.vallabhenterprises.com \\ \textbf{E}: vallabhsecure@yahoo.co.in \\ \end{cases}$

Service Status Details : VE4100									
Priority:	Low								
Created By:	Admin - Apurva Vajaria								
Complaint Mob. No. :	9892982500								
Technician Name :	Atique Salmani		Technician Mobile :	8080922984					
Ticket Type :	Complain	Complain Date & Time:		7					
Vendor Details :									
Company Name/Client Name :	Lifescapes Mirage	Customer's Mobile :	9892982500	Name :	Rakesh Sanghavi				
Address:									
Mumbai,,,400028, Maharashtra									
AMC Details :									
Expiry Date :	01-01-1970 05:30:00		Type:						
Product Name:	CCTV								
Complain:	Need to check all floor off cameras								
Technician Comment :	Mirage lifespace 1.Tvt dvr no.1 camera nmbr 12 cable ok camera faulty. Location office. 2.camera nmbr 15 16 floor check cable contineti and reconnect working ok Hikvision dvr camera nmbr 7 ramp dome camera faulty cable ok. Hikvision dvr camera nmbr 8 a 15 floor line ok cable ok camera faulty dome 16 693 camera refiilled bnc dc aftr check cable contineti it was disconnect now working ok . 5 floor strease camera ok cable faulty 5 floor passages cable missing need to lay new cable								
Complain Operator :	Desktop - Apurva Vajaria								
Remark :	Mirage lifespace 1.Tvt dvr no.1 camera nmbr 12 cable ok camera faulty. Location office. 2.camera nmbr 15 16 floor check cable contineti and reconnect working ok Hikvision dvr camera nmbr 7 ramp dome camera faulty cable ok. Hikvision dvr camera nmbr 8 a 15 floor line ok cable ok camera faulty dome 16 693 camera refiilled bnc dc aftr check cable contineti it was disconnect now working ok . 5 floor strease camera ok cable faulty 5 floor passages cable missing need to lay new cable								

Status History :	Date Time	Technician Name	St	tatus	Remark	Sign	
	23-10-2021 06:40:15	Atique Salmani	Com	npleted	Mirage lifespace 1.Tvt dvr no.1 camera nmbr 12 cable ok camera faulty. Location office. 2.camera nmbr 15 16 floor check cable contineti and reconnect working ok Hikvision dvr camera nmbr 7 ramp dome camera faulty cable ok. Hikvision dvr camera nmbr 8 a 15 floor line ok cable ok camera faulty dome 16 693 camera refiilled bnc dc aftr check cable contineti it was disconnet now working ok . 5 floor strease camera ok cable faulty 5 floor passages cable missing need to lay new cable	23/10/21	
	23-10-2021 03:04:28	Atique Salmani	New			-	
	23-10-2021 03:04:17	Atique Salmani	New	V		-	
Previous Complain History :	Date Time	Date Time Technician Na		Remark			
	15-02-2022 02:38:30 YogeshDesa						
	15-02-2022 02:37:1	3 YogeshDesai	YogeshDesai		New phone installed in 805 working ok.		