




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12291																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	7021671156																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	AMC visiting	Date & Time :	31-07-2024 02:23:34																	
Vendor Details :																				
Company Name/Client Name :	Lokhandwala Foundation	Customer's Mobile :	7021671156	Name :	Rauf Sir															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Ppm																			
Complain :	CCTV/PA/EPABX PPM need to do and 1 camera demo need to do																			
Technician Comment :	Demo done by new dvr n new camera and reinstall old 2 cameras afr demo and 3 dvr only make check list ppm painding.																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Demo done by new dvr n new camera and reinstall old 2 cameras afr demo and 3 dvr only make check list ppm painding.																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>31-07-2024 05:50:50</td><td>Atique Salmani</td><td>Work Pending</td><td>Demo done by new dvr n new camera and reinstall old 2 cameras afr demo and 3 dvr only make check list ppm painding.</td><td></td></tr><tr><td>31-07-2024 02:23:41</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	31-07-2024 05:50:50	Atique Salmani	Work Pending	Demo done by new dvr n new camera and reinstall old 2 cameras afr demo and 3 dvr only make check list ppm painding.		31-07-2024 02:23:41	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
31-07-2024 05:50:50	Atique Salmani	Work Pending	Demo done by new dvr n new camera and reinstall old 2 cameras afr demo and 3 dvr only make check list ppm painding.																	
31-07-2024 02:23:41	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>10-09-2024 03:55:19</td><td></td><td></td></tr><tr><td>22-08-2024 12:25:12</td><td>Atique Salmani</td><td>Ppm of cctv pa system and also epbax done 2nd floor camera nmbr 4 cable faulty power not getting also ohms drop so camera off . 1st floor camera nmbr 4 reconnection done camera disturbance need to changed 2 camera cable swap from 7 nmbr dvr to 6 nmbr dvr And back side gate staircase bullet camera water inserted in camera so camera faulty so collect for chek .</td></tr></tbody></table>					Date Time	Technician Name	Remark	10-09-2024 03:55:19			22-08-2024 12:25:12	Atique Salmani	Ppm of cctv pa system and also epbax done 2nd floor camera nmbr 4 cable faulty power not getting also ohms drop so camera off . 1st floor camera nmbr 4 reconnection done camera disturbance need to changed 2 camera cable swap from 7 nmbr dvr to 6 nmbr dvr And back side gate staircase bullet camera water inserted in camera so camera faulty so collect for chek .						
Date Time	Technician Name	Remark																		
10-09-2024 03:55:19																				
22-08-2024 12:25:12	Atique Salmani	Ppm of cctv pa system and also epbax done 2nd floor camera nmbr 4 cable faulty power not getting also ohms drop so camera off . 1st floor camera nmbr 4 reconnection done camera disturbance need to changed 2 camera cable swap from 7 nmbr dvr to 6 nmbr dvr And back side gate staircase bullet camera water inserted in camera so camera faulty so collect for chek .																		