




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12679																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	7021671156																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	Complain	Date & Time :	10-09-2024 03:55:19																	
Vendor Details :																				
Company Name/Client Name :	Lokhandwala Foundation	Customer's Mobile :	7021671156	Name :	Rauf Sir															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	pa																			
Complain :	8-10 Nos PA Speakers not working																			
Technician Comment :	401 connections was removed reconnect working ok 402.403.404loop break so loop from 402 passage spaekers working ok and 410 spaker faulty need to changed rauf sir need spaekers price .																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	401 connections was removed reconnect working ok 402.403.404loop break so loop from 402 passage spaekers working ok and 410 spaker faulty need to changed rauf sir need spaekers price .																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>12-09-2024 04:17:38</td><td>Atique Salmani</td><td>Completed</td><td>401 connections was removed reconnect working ok 402.403.404loop break so loop from 402 passage spaekers working ok and 410 spaker faulty need to changed rauf sir need spaekers price .</td><td></td></tr><tr><td>12-09-2024 10:30:37</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	12-09-2024 04:17:38	Atique Salmani	Completed	401 connections was removed reconnect working ok 402.403.404loop break so loop from 402 passage spaekers working ok and 410 spaker faulty need to changed rauf sir need spaekers price .		12-09-2024 10:30:37	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
12-09-2024 04:17:38	Atique Salmani	Completed	401 connections was removed reconnect working ok 402.403.404loop break so loop from 402 passage spaekers working ok and 410 spaker faulty need to changed rauf sir need spaekers price .																	
12-09-2024 10:30:37	Atique Salmani	New		-																

Previous Complain History :			
	Date Time	Technician Name	Remark
	28-11-2024 10:39:51	Atique Salmani	Ppm done of cctv and pa systems and intercom Dvr number 2 hdd issue removed and hand over to rauf sir only live view in dvr nmbr 2 And dvr date n time reset Gr 4 Ground floor camera faulty need to changed 2 2nd floor camera nmbr 3power cable break .4 . And ohms didn't get .cameras of passages . 103 vedeo loss camera faulty need to changed . 4th floor staff room instrument key pad issue . Also 3rd floor instrument issue Second floor ok working propr 1st floor ok working ok And total camera 67 .
	30-09-2024 01:17:16	Atique Salmani	