

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE1970																														
Priority :	High																													
Created By :	Admin - Apurva Vajaria																													
Complaint Mob. No. :	9930088244																													
Technician Name :	Rishi Desai		Technician Mobile :	8369234074																										
Ticket Type :	Complain	Date & Time :	06-10-2020 10:45:54																											
Vendor Details :																														
Company Name/Client Name :	Electromech Fire Fighters Pvt Ltd	Customer's Mobile :	9930088244	Name :	Sailesh Sir																									
Address :																														
Mumbai , , , , Maharashtra																														
AMC Details :																														
Expiry Date :	01-01-1970 05:30:00		Type :																											
Product Name :	Intercom																													
Complain :	manoj sir cabin motion sensor issue																													
Technician Comment :	changed battery for manoj sir cabin now under observation rest checked system all working fine																													
Complain Operator :	Desktop - Apurva Vajaria																													
Remark :	changed battery for manoj sir cabin now under observation rest checked system all working fine																													
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>24-10-2020 02:57:55</td><td>RishiDesai</td><td>Completed</td><td>changed battery for manoj sir cabin now under observation rest checked system all working fine</td><td></td></tr><tr><td>24-10-2020 02:56:00</td><td>RishiDesai</td><td>New</td><td></td><td>-</td></tr><tr><td>07-10-2020 10:17:26</td><td>RishiDesai</td><td>New</td><td></td><td>-</td></tr><tr><td>06-10-2020 10:45:54</td><td>RishiDesai</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	24-10-2020 02:57:55	RishiDesai	Completed	changed battery for manoj sir cabin now under observation rest checked system all working fine		24-10-2020 02:56:00	RishiDesai	New		-	07-10-2020 10:17:26	RishiDesai	New		-	06-10-2020 10:45:54	RishiDesai	New		-
Date Time	Technician Name	Status	Remark	Sign																										
24-10-2020 02:57:55	RishiDesai	Completed	changed battery for manoj sir cabin now under observation rest checked system all working fine																											
24-10-2020 02:56:00	RishiDesai	New		-																										
07-10-2020 10:17:26	RishiDesai	New		-																										
06-10-2020 10:45:54	RishiDesai	New		-																										
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>25-01-2021 02:03:36</td><td>MayurYadav</td><td>2motion sensor temp. issue solve hooter not sound battery low</td></tr><tr><td>25-09-2020 10:32:37</td><td>YashDoshi</td><td>check all system siren battery low and all sensor check working ok. in keypad of jablotron some liquid form as sanetizer so not coming display.</td></tr></tbody></table>					Date Time	Technician Name	Remark	25-01-2021 02:03:36	MayurYadav	2motion sensor temp. issue solve hooter not sound battery low	25-09-2020 10:32:37	YashDoshi	check all system siren battery low and all sensor check working ok. in keypad of jablotron some liquid form as sanetizer so not coming display.																
Date Time	Technician Name	Remark																												
25-01-2021 02:03:36	MayurYadav	2motion sensor temp. issue solve hooter not sound battery low																												
25-09-2020 10:32:37	YashDoshi	check all system siren battery low and all sensor check working ok. in keypad of jablotron some liquid form as sanetizer so not coming display.																												