



Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE5112					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9167359050				
Technician Name :	Atique Salmani		Technician Mobile :	8080922984	
Ticket Type :	Complain	Date & Time :	30-03-2022 09:59:56		
Vendor Details :					
Company Name/Client Name :	Bombay Deying And Manufacturing Co. Ltd	Customer's Mobile :	9167359050	Name :	Sandeep Sir
Address :					
Mumbai , , , , Maharashtra					
AMC Details :					
Expiry Date :	31-07-2020 12:00:00		Type :	Comprehensive	
Product Name :	Access				
Complain :	access issue need to check				
Technician Comment :	Total 8 door access Second floor 1 door access Ground floor 2 door access Chairman confrence room door not realising by exit swich need to recheck becز chairman is there no permission for work Ground floor vip lift area SMPS faulty need to changed				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	Total 8 door access Second floor 1 door access Ground floor 2 door access Chairman confrence room door not realising by exit swich need to recheck becز chairman is there no permission for work Ground floor vip lift area SMPS faulty need to changed				

Status History :	Date Time	Technician Name	Status	Remark	Sign
	06-04-2022 11:22:21	Atique Salmani	Work Pending	Total 8 door access Second floor 1 door access Ground floor 2 door access Chairman confrence room door not realising by exit swich need to recheck becuz chairman is there no permission for work Ground floor vip lift area SMPS faulty need to changed	
	06-04-2022 10:02:53	Atique Salmani	New		-
	31-03-2022 04:03:26	Atique Salmani	Work Pending		-
	30-03-2022 11:48:18	Atique Salmani	Completed	access door need to check but power supply issue 12 volt DC other power supply used working but only for testing inform to vashant Bidwe (maintenance parson)	
	30-03-2022 10:00:32	Atique Salmani	New		-
	30-03-2022 09:59:56	Atique Salmani	New		-
Previous Complain History :	Date Time	Technician Name	Remark		
	15-03-2022 11:15:29	Prashant Nikalje	power supply on All door lock work but same access device not working need to check cabling and device .-		
	27-12-2021 10:54:12	Neeraj Chauhan	all camera cleaning house and lence and times date checking and dvr functions check and 8 camera no video issues solve and camera working OK. ppm done.		