

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE10290															
Priority :	Low														
Created By :	Admin - Apurva Vajaria														
Complaint Mob. No. :	9049503080														
Technician Name :	Mayur Yadav		Technician Mobile :	8411951301											
Ticket Type :	Complain	Date & Time :	16-12-2023 10:51:25												
Vendor Details :															
Company Name/Client Name :	ALLIANZ TECHNOLOGY SE(PHASE I)	Customer's Mobile :	9049503080	Name :	Satyam Sir										
Address :															
Mumbai , , , , Maharashtra															
AMC Details :															
Expiry Date :	30-10-2020 12:00:00		Type :	Comprehensive											
Product Name :	Fire														
Complain :	Power Box error in Cluster C 4th Floor FAS Panel.														
Technician Comment :															
Complain Operator :	Desktop - Apurva Vajaria														
Remark :															
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>16-12-2023 10:52:35</td><td>MayurYadav</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	16-12-2023 10:52:35	MayurYadav	New		-
Date Time	Technician Name	Status	Remark	Sign											
16-12-2023 10:52:35	MayurYadav	New		-											
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>28-12-2024 11:22:16</td><td>Siddhesh Chavan</td><td></td></tr><tr><td>23-11-2024 12:05:23</td><td>MayurYadav</td><td>4th floor beam detector fault solve Beam detector power MCB off when on beam detector working ok 5 th floor detector remove alarm explain Camera remove explain</td></tr></tbody></table>					Date Time	Technician Name	Remark	28-12-2024 11:22:16	Siddhesh Chavan		23-11-2024 12:05:23	MayurYadav	4th floor beam detector fault solve Beam detector power MCB off when on beam detector working ok 5 th floor detector remove alarm explain Camera remove explain	
Date Time	Technician Name	Remark													
28-12-2024 11:22:16	Siddhesh Chavan														
23-11-2024 12:05:23	MayurYadav	4th floor beam detector fault solve Beam detector power MCB off when on beam detector working ok 5 th floor detector remove alarm explain Camera remove explain													