

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12825															
Priority :	Low														
Created By :	Admin - Apurva Vajaria														
Complaint Mob. No. :	9049503080														
Technician Name :	Siddhesh Chavan		Technician Mobile :	8080922985											
Ticket Type :	AMC visiting	Date & Time :	27-09-2024 04:04:35												
Vendor Details :															
Company Name/Client Name :	ALLIANZ TECHNOLOGY SE(PHASE I)	Customer's Mobile :	9049503080	Name :	Satyam Sir										
Address :															
Mumbai , , , , Maharashtra															
AMC Details :															
Expiry Date :	30-10-2020 12:00:00		Type :	Comprehensive											
Product Name :	Ppm														
Complain :	CCTV/FAS/PA/Intrusion PPM Need to do														
Technician Comment :															
Complain Operator :	Desktop - Apurva Vajaria														
Remark :															
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>27-09-2024 04:04:44</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	27-09-2024 04:04:44	Siddhesh Chavan	New		-
Date Time	Technician Name	Status	Remark	Sign											
27-09-2024 04:04:44	Siddhesh Chavan	New		-											
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>23-11-2024 12:05:23</td><td>MayurYadav</td><td>4th floor beam detector fault solve Beam detector power MCB off when on beam detector working ok 5 th floor detector remove alarm explain Camera remove explain</td></tr><tr><td>22-06-2024 12:04:47</td><td>Siddhesh Chavan</td><td>CCTV/FAS/PA/Intrusion PPM done.</td></tr></tbody></table>					Date Time	Technician Name	Remark	23-11-2024 12:05:23	MayurYadav	4th floor beam detector fault solve Beam detector power MCB off when on beam detector working ok 5 th floor detector remove alarm explain Camera remove explain	22-06-2024 12:04:47	Siddhesh Chavan	CCTV/FAS/PA/Intrusion PPM done.	
Date Time	Technician Name	Remark													
23-11-2024 12:05:23	MayurYadav	4th floor beam detector fault solve Beam detector power MCB off when on beam detector working ok 5 th floor detector remove alarm explain Camera remove explain													
22-06-2024 12:04:47	Siddhesh Chavan	CCTV/FAS/PA/Intrusion PPM done.													