










Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE4037																																								
Priority :	Low																																							
Created By :	Admin - Apurva Vajaria																																							
Complaint Mob. No. :	2239417700																																							
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																																				
Ticket Type :	Complain	Date & Time :	14-10-2021 10:28:07																																					
Vendor Details :																																								
Company Name/Client Name :	Beam Hospital (Womens Hospital)	Customer's Mobile :	2239417700	Name :	Shazia																																			
Address :																																								
Mumbai , , , , Maharashtra																																								
AMC Details :																																								
Expiry Date :	30-09-2020 12:00:00		Type :	Comprehensive																																				
Product Name :	Fire																																							
Complain :	fire alarm kept off some fault in panel																																							
Technician Comment :	terrace new hooter installed and working ok ground check both hooter ground and terrace working ok.all zones normal .																																							
Complain Operator :	Desktop - Apurva Vajaria																																							
Remark :	terrace new hooter installed and working ok ground check both hooter ground and terrace working ok.all zones normal .																																							
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>20-10-2021 12:05:02</td><td>Atique Salmani</td><td>Completed</td><td>terrace new hooter installed and working ok ground check both hooter ground and terrace working ok.all zones normal .</td><td></td></tr><tr><td>18-10-2021 05:57:10</td><td>Atique Salmani</td><td>Work Pending</td><td>4 zone pannel installed and working ok only terrace hooter issue need to changed ppm done .</td><td></td></tr><tr><td>17-10-2021 01:53:26</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>14-10-2021 12:25:57</td><td>Atique Salmani</td><td>Work Pending</td><td>fire panel check display issue ground floor zone open checking pending bcz pesent in floor not check smoke detector in OT room</td><td></td></tr><tr><td>14-10-2021 10:28:39</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>14-10-2021 10:28:07</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	20-10-2021 12:05:02	Atique Salmani	Completed	terrace new hooter installed and working ok ground check both hooter ground and terrace working ok.all zones normal .		18-10-2021 05:57:10	Atique Salmani	Work Pending	4 zone pannel installed and working ok only terrace hooter issue need to changed ppm done .		17-10-2021 01:53:26	Atique Salmani	New		-	14-10-2021 12:25:57	Atique Salmani	Work Pending	fire panel check display issue ground floor zone open checking pending bcz pesent in floor not check smoke detector in OT room		14-10-2021 10:28:39	Atique Salmani	New		-	14-10-2021 10:28:07	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																																				
20-10-2021 12:05:02	Atique Salmani	Completed	terrace new hooter installed and working ok ground check both hooter ground and terrace working ok.all zones normal .																																					
18-10-2021 05:57:10	Atique Salmani	Work Pending	4 zone pannel installed and working ok only terrace hooter issue need to changed ppm done .																																					
17-10-2021 01:53:26	Atique Salmani	New		-																																				
14-10-2021 12:25:57	Atique Salmani	Work Pending	fire panel check display issue ground floor zone open checking pending bcz pesent in floor not check smoke detector in OT room																																					
14-10-2021 10:28:39	Atique Salmani	New		-																																				
14-10-2021 10:28:07	Atique Salmani	New		-																																				

Previous Complain History :	Date Time	Technician Name	Remark
	17-10-2021 01:55:46	Atique Salmani	Smoke detector clean and all cameras lens clean and fire alarm pannel beeper issue and hooter and no.nc.common port issue need to changed pannel . work paining and also checklist of cameras paining. Pannel display issue keypad issue . Also changed 4 zone pannel new now only terrace hooter need to changed .
	08-10-2021 09:54:19	Siddhesh Chavan	dvr online in mobile and all camera working ok