

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE10708																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9819049156																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	AMC visiting	Date & Time :	31-01-2024 02:49:04																	
Vendor Details :																				
Company Name/Client Name :	Sotex India Pvt Ltd - Turbhe	Customer's Mobile :	9819049156	Name :	Shreeram Sir															
Address :																				
Mumbai , , , 400705 , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Ppm																			
Complain :	Fire/Access Control system PPM need to do																			
Technician Comment :	Check fire alarm pannel and also arnfumly chek all s.d .detectors clean pannel chek battery voltage ok And also check boath door access working ok .																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Check fire alarm pannel and also arnfumly chek all s.d .detectors clean pannel chek battery voltage ok And also check boath door access working ok .																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>14-02-2024 01:07:27</td><td>Atique Salmani</td><td>Completed</td><td>Check fire alarm pannel and also arnfumly chek all s.d .detectors clean pannel chek battery voltage ok And also check boath door access working ok .</td><td></td></tr><tr><td>13-02-2024 10:42:12</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	14-02-2024 01:07:27	Atique Salmani	Completed	Check fire alarm pannel and also arnfumly chek all s.d .detectors clean pannel chek battery voltage ok And also check boath door access working ok .		13-02-2024 10:42:12	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
14-02-2024 01:07:27	Atique Salmani	Completed	Check fire alarm pannel and also arnfumly chek all s.d .detectors clean pannel chek battery voltage ok And also check boath door access working ok .																	
13-02-2024 10:42:12	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>14-03-2024 10:51:14</td><td>Ravi Rajbhar</td><td></td></tr><tr><td>20-02-2024 12:40:47</td><td>Atique Salmani</td><td>Pannel need to collect for for service center cheking .</td></tr></tbody></table>					Date Time	Technician Name	Remark	14-03-2024 10:51:14	Ravi Rajbhar		20-02-2024 12:40:47	Atique Salmani	Pannel need to collect for for service center cheking .						
Date Time	Technician Name	Remark																		
14-03-2024 10:51:14	Ravi Rajbhar																			
20-02-2024 12:40:47	Atique Salmani	Pannel need to collect for for service center cheking .																		