




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE11448																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9819049156																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	Complain	Date & Time :	24-04-2024 10:34:23																	
Vendor Details :																				
Company Name/Client Name :	Sotex India Pvt Ltd - Turbhe	Customer's Mobile :	9819049156	Name :	Shreeram Sir															
Address :																				
Mumbai , , , 400705 , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Access																			
Complain :	require attendance data in sandeep sir pc and cCTV access also required in sandeep sir																			
Technician Comment :	Biomax n ivms software download in sandip sir pc and locally view ok but dvr date n time issue so changed c moss battery dvr on but mouse n vga output issue so collect dvr for check .																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Biomax n ivms software download in sandip sir pc and locally view ok but dvr date n time issue so changed c moss battery dvr on but mouse n vga output issue so collect dvr for check .																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>26-04-2024 05:52:25</td><td>Atique Salmani</td><td>Work Pending</td><td>Biomax n ivms software download in sandip sir pc and locally view ok but dvr date n time issue so changed c moss battery dvr on but mouse n vga output issue so collect dvr for check .</td><td></td></tr><tr><td>25-04-2024 06:28:45</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	26-04-2024 05:52:25	Atique Salmani	Work Pending	Biomax n ivms software download in sandip sir pc and locally view ok but dvr date n time issue so changed c moss battery dvr on but mouse n vga output issue so collect dvr for check .		25-04-2024 06:28:45	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
26-04-2024 05:52:25	Atique Salmani	Work Pending	Biomax n ivms software download in sandip sir pc and locally view ok but dvr date n time issue so changed c moss battery dvr on but mouse n vga output issue so collect dvr for check .																	
25-04-2024 06:28:45	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>05-11-2024 11:45:49</td><td>Rahul Mhapralkar</td><td>PPM DONE all smoke device working normally, all devices cleaning and checking.</td></tr><tr><td>10-07-2024 12:25:13</td><td>Rahul Mhapralkar</td><td>Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office</td></tr></tbody></table>					Date Time	Technician Name	Remark	05-11-2024 11:45:49	Rahul Mhapralkar	PPM DONE all smoke device working normally, all devices cleaning and checking.	10-07-2024 12:25:13	Rahul Mhapralkar	Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office						
Date Time	Technician Name	Remark																		
05-11-2024 11:45:49	Rahul Mhapralkar	PPM DONE all smoke device working normally, all devices cleaning and checking.																		
10-07-2024 12:25:13	Rahul Mhapralkar	Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office																		