


Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12115					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9819049156				
Technician Name :	Rahul Mhapralkar		Technician Mobile :	9168762949	
Ticket Type :	AMC visiting	Date & Time :	10-07-2024 12:25:13		
Vendor Details :					
Company Name/Client Name :	Sotex India Pvt Ltd - Turbhe	Customer's Mobile :	9819049156	Name :	Shreeram Sir
Address :					
Mumbai , , , 400705 , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Ppm				
Complain :	Fire/Access PPM need to do				
Technician Comment :	Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office				
Status History :	Date Time	Technician Name	Status	Remark	Sign
	31-07-2024 02:45:08	Rahul Mhapralkar	Completed	Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office	
	30-07-2024 07:47:27	Rahul Mhapralkar	New		-
	10-07-2024 12:25:20	Rahul Mhapralkar	New		-

Previous Complain History :			
	Date Time	Technician Name	Remark
	05-11-2024 11:45:49	Rahul Mhapralkar	PPM DONE all smoke device working normally, all devices cleaning and checking.
	24-04-2024 10:34:23	Atique Salmani	Biomax n ivms software download in sandip sir pc and locally view ok but dvr date n time issue so changed c moss battery dvr on but mouse n vga output issue so collect dvr for check .