

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE14125															
Priority :	Low														
Created By :	Admin - Apurva Vajaria														
Complaint Mob. No. :	9819049156														
Technician Name :	Santosh Pathak		Technician Mobile :	8080922980											
Ticket Type :	New Installation	Date & Time :	20-02-2025 12:24:41												
Vendor Details :															
Company Name/Client Name :	Sotex India Pvt Ltd - Turbhe	Customer's Mobile :	9819049156	Name :	Shreeram Sir										
Address :															
Mumbai , , , 400705 , Maharashtra															
AMC Details :															
Expiry Date :	01-01-1970 05:30:00		Type :												
Product Name :	CCTV														
Complain :	CCTV Installation with cabling														
Technician Comment :															
Complain Operator :	Desktop - Apurva Vajaria														
Remark :															
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>20-02-2025 12:24:52</td><td>SantoshPathak</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	20-02-2025 12:24:52	SantoshPathak	New		-
Date Time	Technician Name	Status	Remark	Sign											
20-02-2025 12:24:52	SantoshPathak	New		-											
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>05-11-2024 11:45:49</td><td>Rahul Mhapralkar</td><td>PPM DONE all smoke device working normally, all devices cleaning and checking.</td></tr><tr><td>10-07-2024 12:25:13</td><td>Rahul Mhapralkar</td><td>Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office</td></tr></tbody></table>					Date Time	Technician Name	Remark	05-11-2024 11:45:49	Rahul Mhapralkar	PPM DONE all smoke device working normally, all devices cleaning and checking.	10-07-2024 12:25:13	Rahul Mhapralkar	Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office	
Date Time	Technician Name	Remark													
05-11-2024 11:45:49	Rahul Mhapralkar	PPM DONE all smoke device working normally, all devices cleaning and checking.													
10-07-2024 12:25:13	Rahul Mhapralkar	Fire & Access Control System PPM Done, need to early quotation of cctv camera DVR (16 channel+ 32 channel) also Covert to ip camera quotation (36 Dome Camera , 3 bullet camera DOME camera installation Qty 36 nos by back Bullet camera installation Qty 3 nos by back Total 39 bos New requirement 7 n0s ip camera for ground floor office													