




# Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
Support : | W : www.vallabhenterprises.com  
E : vallabhsecure@yahoo.co.in

<b>Service Status Details : VE11847</b>																				
<b>Priority :</b>	Low																			
<b>Created By :</b>	Admin - Apurva Vajaria																			
<b>Complaint Mob. No. :</b>	9922942248																			
<b>Technician Name :</b>	Neeraj Chauhan		<b>Technician Mobile :</b>	8898885764																
<b>Ticket Type :</b>	Complain	<b>Date &amp; Time :</b>	08-06-2024 11:06:09																	
<b>Vendor Details :</b>																				
Company Name/Client Name :	Brookhil Chs	Customer's Mobile :	9922942248	Name :	Swati Mam															
<b>Address :</b>																				
Mumbai , , , , Maharashtra																				
<b>AMC Details :</b>																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
<b>Product Name :</b>	CCTV																			
<b>Complain :</b>	Ground floor recording issue HDD error																			
<b>Technician Comment :</b>	System under objarvation																			
<b>Complain Operator :</b>	Desktop - Apurva Vajaria																			
<b>Remark :</b>	System under objarvation																			
<b>Status History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>10-06-2024 04:50:31</td><td>Neeraj Chauhan</td><td>Completed</td><td>System under objarvation</td><td></td></tr><tr><td>10-06-2024 11:13:54</td><td>Neeraj Chauhan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	10-06-2024 04:50:31	Neeraj Chauhan	Completed	System under objarvation		10-06-2024 11:13:54	Neeraj Chauhan	New		-
Date Time	Technician Name	Status	Remark	Sign																
10-06-2024 04:50:31	Neeraj Chauhan	Completed	System under objarvation																	
10-06-2024 11:13:54	Neeraj Chauhan	New		-																
<b>Previous Complain History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>25-06-2024 10:28:11</td><td>Atique Salmani</td><td>Power consumption so lift camera become off and now it's working ok and 2401 intercom issue resolved by from duct side cable issue so swap cable and working ok and basement exit switch issue sonthere is asmall swich in sapare so use that switch working ok but need big size swich in next visit all cctv working ok.</td></tr><tr><td>22-06-2024 11:58:09</td><td>Atique Salmani</td><td>All cameras lence cleaning done and one camera issue resolved. And also all intercom working and 4 door access working ok.</td></tr></tbody></table>					Date Time	Technician Name	Remark	25-06-2024 10:28:11	Atique Salmani	Power consumption so lift camera become off and now it's working ok and 2401 intercom issue resolved by from duct side cable issue so swap cable and working ok and basement exit switch issue sonthere is asmall swich in sapare so use that switch working ok but need big size swich in next visit all cctv working ok.	22-06-2024 11:58:09	Atique Salmani	All cameras lence cleaning done and one camera issue resolved. And also all intercom working and 4 door access working ok.						
Date Time	Technician Name	Remark																		
25-06-2024 10:28:11	Atique Salmani	Power consumption so lift camera become off and now it's working ok and 2401 intercom issue resolved by from duct side cable issue so swap cable and working ok and basement exit switch issue sonthere is asmall swich in sapare so use that switch working ok but need big size swich in next visit all cctv working ok.																		
22-06-2024 11:58:09	Atique Salmani	All cameras lence cleaning done and one camera issue resolved. And also all intercom working and 4 door access working ok.																		