




# Vallabh Enterprises

**Regd. Office :** 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
**Support : | W :** www.vallabhenterprises.com  
**E :** vallabhsecure@yahoo.co.in

<b>Service Status Details : VE4287</b>																														
<b>Priority :</b>	Low																													
<b>Created By :</b>	Admin - Apurva Vajaria																													
<b>Complaint Mob. No. :</b>	9167588545																													
<b>Technician Name :</b>	Atique Salmani		<b>Technician Mobile :</b>	8080922984																										
<b>Ticket Type :</b>	Complain	<b>Date &amp; Time :</b>	27-11-2021 10:30:32																											
<b>Vendor Details :</b>																														
<b>Company Name/Client Name :</b>	Vimla Villa Vaibhav Sir Home	<b>Customer's Mobile :</b>	9167588545	<b>Name :</b>	Vaibhav Doshi																									
<b>Address :</b>																														
Mumbai , , , , Maharashtra																														
<b>AMC Details :</b>																														
<b>Expiry Date :</b>	01-01-1970 05:30:00		<b>Type :</b>																											
<b>Product Name :</b>	VDP																													
<b>Complain :</b>	bell issue																													
<b>Technician Comment :</b>	exit swich issue from 6 floor and lock not working so exit swich cable check ncontinuti and reconnection working ok all cannection reconection from lobby pannel becoz cables was rushted..now all working ok.																													
<b>Complain Operator :</b>	Desktop - Apurva Vajaria																													
<b>Remark :</b>	exit swich issue from 6 floor and lock not working so exit swich cable check ncontinuti and reconnection working ok all cannection reconection from lobby pannel becoz cables was rushted..now all working ok.																													
<b>Status History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>29-11-2021 04:06:08</td><td>Atique Salmani</td><td>Closed</td><td></td><td>-</td></tr><tr><td>27-11-2021 01:47:32</td><td>Atique Salmani</td><td>Completed</td><td>exit swich issue from 6 floor and lock not working so exit swich cable check ncontinuti and reconnection working ok all cannection reconection from lobby pannel becoz cables was rushted..now all working ok.</td><td></td></tr><tr><td>27-11-2021 10:30:50</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>27-11-2021 10:30:32</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	29-11-2021 04:06:08	Atique Salmani	Closed		-	27-11-2021 01:47:32	Atique Salmani	Completed	exit swich issue from 6 floor and lock not working so exit swich cable check ncontinuti and reconnection working ok all cannection reconection from lobby pannel becoz cables was rushted..now all working ok.		27-11-2021 10:30:50	Atique Salmani	New		-	27-11-2021 10:30:32	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																										
29-11-2021 04:06:08	Atique Salmani	Closed		-																										
27-11-2021 01:47:32	Atique Salmani	Completed	exit swich issue from 6 floor and lock not working so exit swich cable check ncontinuti and reconnection working ok all cannection reconection from lobby pannel becoz cables was rushted..now all working ok.																											
27-11-2021 10:30:50	Atique Salmani	New		-																										
27-11-2021 10:30:32	Atique Salmani	New		-																										
<b>Previous Complain History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody></tbody></table>					Date Time	Technician Name	Remark																						
Date Time	Technician Name	Remark																												