







Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE13096																														
Priority :	Low																													
Created By :	Admin - Apurva Vajaria																													
Complaint Mob. No. :	7352454804																													
Technician Name :	Sonu Kumar		Technician Mobile :	8454016444																										
Ticket Type :	Complain	Date & Time :	24-10-2024 11:39:17																											
Vendor Details :																														
Company Name/Client Name :	Rahul International - Mira Road	Customer's Mobile :	7352454804	Name :	Vikash Sir																									
Address :																														
Mumbai , , , , Maharashtra																														
AMC Details :																														
Expiry Date :	01-01-1970 05:30:00		Type :																											
Product Name :	CCTV																													
Complain :	1)8th floor councilor room outside 1 camera off 2)ground floor cEO cabin 1 camera off 3)Recording how many days going need to check																													
Technician Comment :	8th floor councilor room outside																													
Complain Operator :	Desktop - Apurva Vajaria																													
Remark :	8th floor councilor room outside																													
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>28-10-2024 01:31:48</td><td>Sonu Kumar</td><td>Completed</td><td>8th floor councilor room outside</td><td></td></tr><tr><td>28-10-2024 10:49:08</td><td>Sonu Kumar</td><td>New</td><td></td><td>-</td></tr><tr><td>25-10-2024 04:22:49</td><td>Sonu Kumar</td><td>Work Pending</td><td>8 floor 1 bullet camera faulty power issue. Take for Repair. 8 floor lift side camera faulty power issue. 8 floor lift side camera Replaced working done. Counseling room no video issue resolved. 3 floor dvr offline issue resolved.all camera working.</td><td></td></tr><tr><td>25-10-2024 10:07:08</td><td>Sonu Kumar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	28-10-2024 01:31:48	Sonu Kumar	Completed	8th floor councilor room outside		28-10-2024 10:49:08	Sonu Kumar	New		-	25-10-2024 04:22:49	Sonu Kumar	Work Pending	8 floor 1 bullet camera faulty power issue. Take for Repair. 8 floor lift side camera faulty power issue. 8 floor lift side camera Replaced working done. Counseling room no video issue resolved. 3 floor dvr offline issue resolved.all camera working.		25-10-2024 10:07:08	Sonu Kumar	New		-
Date Time	Technician Name	Status	Remark	Sign																										
28-10-2024 01:31:48	Sonu Kumar	Completed	8th floor councilor room outside																											
28-10-2024 10:49:08	Sonu Kumar	New		-																										
25-10-2024 04:22:49	Sonu Kumar	Work Pending	8 floor 1 bullet camera faulty power issue. Take for Repair. 8 floor lift side camera faulty power issue. 8 floor lift side camera Replaced working done. Counseling room no video issue resolved. 3 floor dvr offline issue resolved.all camera working.																											
25-10-2024 10:07:08	Sonu Kumar	New		-																										

Previous Complain History :	Date Time	Technician Name	Remark
	12-11-2024 04:35:42	Sonu Kumar	Cctv ppm done and ground NVR not working issue resolved working ok
	18-10-2024 10:16:00		