

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE2778																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9833373329																								
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																					
Ticket Type :	Complain	Date & Time :	05-03-2021 10:05:21																						
Vendor Details :																									
Company Name/Client Name :	Shoppers Stop Ltd - Bandra	Customer's Mobile :	9833373329	Name :	Vishnu Shinde																				
Address :																									
Mumbai , , , 400050 , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Ppm																								
Complain :	Fas and ias system																								
Technician Comment :	ppm done of fire panal and intrusion Faulty detector Loop 1 - 11 Loop 2 - 16 Total divec 143 Instusion also ok working only line issue 37 detector cleen up																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	ppm done of fire panal and intrusion Faulty detector Loop 1 - 11 Loop 2 - 16 Total divec 143 Instusion also ok working only line issue 37 detector cleen up																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>05-03-2021 04:54:24</td><td>Ravi Rajbhar</td><td>Completed</td><td>ppm done of fire panal and intrusion Faulty detector Loop 1 - 11 Loop 2 - 16 Total divec 143 Instusion also ok working only line issue 37 detector cleen up</td><td></td></tr><tr><td>05-03-2021 10:05:40</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>05-03-2021 10:05:21</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	05-03-2021 04:54:24	Ravi Rajbhar	Completed	ppm done of fire panal and intrusion Faulty detector Loop 1 - 11 Loop 2 - 16 Total divec 143 Instusion also ok working only line issue 37 detector cleen up		05-03-2021 10:05:40	Ravi Rajbhar	New		-	05-03-2021 10:05:21	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
05-03-2021 04:54:24	Ravi Rajbhar	Completed	ppm done of fire panal and intrusion Faulty detector Loop 1 - 11 Loop 2 - 16 Total divec 143 Instusion also ok working only line issue 37 detector cleen up																						
05-03-2021 10:05:40	Ravi Rajbhar	New		-																					
05-03-2021 10:05:21	Ravi Rajbhar	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>20-04-2022 11:09:54</td><td>Shiva Meena</td><td>hard disk error parobalam 1 hard disk ok 2 tb</td></tr><tr><td>01-02-2022 12:31:02</td><td>AnilYadav</td><td></td></tr></tbody></table>					Date Time	Technician Name	Remark	20-04-2022 11:09:54	Shiva Meena	hard disk error parobalam 1 hard disk ok 2 tb	01-02-2022 12:31:02	AnilYadav												
Date Time	Technician Name	Remark																							
20-04-2022 11:09:54	Shiva Meena	hard disk error parobalam 1 hard disk ok 2 tb																							
01-02-2022 12:31:02	AnilYadav																								