




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE2819																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9833373329																								
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																					
Ticket Type :	Complain	Date & Time :	11-03-2021 06:19:50																						
Vendor Details :																									
Company Name/Client Name :	Shoppers Stop Ltd - Bandra	Customer's Mobile :	9833373329	Name :	Vishnu Shinde																				
Address :																									
Mumbai , , , 400050 , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	intrusion																								
Complain :	intrusion and fire checking balance pending																								
Technician Comment :	1 , 2, 4 ,5 fire exit door cable check. door working ok when door opens hooter works ground floor one panic switch issue .1,2,3,4 cash counter panic switch working ok when pressed hooter works . all fire doors and panic switch working shown to maintaince person . how to disarm and arm also shown to maintaince person 3 th floor fire exit cable missing																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	1 , 2, 4 ,5 fire exit door cable check. door working ok when door opens hooter works ground floor one panic switch issue .1,2,3,4 cash counter panic switch working ok when pressed hooter works . all fire doors and panic switch working shown to maintaince person . how to disarm and arm also shown to maintaince person 3 th floor fire exit cable missing																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>12-03-2021 07:22:55</td><td>Ravi Rajbhar</td><td>Completed</td><td>1 , 2, 4 ,5 fire exit door cable check. door working ok when door opens hooter works ground floor one panic switch issue .1,2,3,4 cash counter panic switch working ok when pressed hooter works . all fire doors and panic switch working shown to maintaince person . how to disarm and arm also shown to maintaince person 3 th floor fire exit cable missing</td><td></td></tr><tr><td>11-03-2021 06:20:48</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>11-03-2021 06:19:50</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	12-03-2021 07:22:55	Ravi Rajbhar	Completed	1 , 2, 4 ,5 fire exit door cable check. door working ok when door opens hooter works ground floor one panic switch issue .1,2,3,4 cash counter panic switch working ok when pressed hooter works . all fire doors and panic switch working shown to maintaince person . how to disarm and arm also shown to maintaince person 3 th floor fire exit cable missing		11-03-2021 06:20:48	Ravi Rajbhar	New		-	11-03-2021 06:19:50	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
12-03-2021 07:22:55	Ravi Rajbhar	Completed	1 , 2, 4 ,5 fire exit door cable check. door working ok when door opens hooter works ground floor one panic switch issue .1,2,3,4 cash counter panic switch working ok when pressed hooter works . all fire doors and panic switch working shown to maintaince person . how to disarm and arm also shown to maintaince person 3 th floor fire exit cable missing																						
11-03-2021 06:20:48	Ravi Rajbhar	New		-																					
11-03-2021 06:19:50	Ravi Rajbhar	New		-																					

Previous Complain History :	Date Time	Technician Name	Remark
	20-04-2022 11:09:54	Shiva Meena	hard disk error parobalam 1 hard disk ok 2 tb
	01-02-2022 12:31:02	AnilYadav	