




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE4349																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9833373329																								
Technician Name :	Siddhesh Chavan	Technician Mobile :	8080922985																						
Ticket Type :	New Installation	Date & Time :	08-12-2021 10:35:10																						
Vendor Details :																									
Company Name/Client Name :	Shoppers Stop Ltd - Jo Malone	Customer's Mobile :	9833373329	Name :	Vishnu Shinde																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Fire																								
Complain :	Installation of fire panel with battery																								
Technician Comment :	new 2 12v 7 Ah backup battery install and fire panel battery status healthy																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	new 2 12v 7 Ah backup battery install and fire panel battery status healthy																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>08-12-2021 10:44:38</td><td>Siddhesh Chavan</td><td>Completed</td><td>new 2 12v 7 Ah backup battery install and fire panel battery status healthy</td><td></td></tr><tr><td>08-12-2021 10:35:22</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr><tr><td>08-12-2021 10:35:10</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	08-12-2021 10:44:38	Siddhesh Chavan	Completed	new 2 12v 7 Ah backup battery install and fire panel battery status healthy		08-12-2021 10:35:22	Siddhesh Chavan	New		-	08-12-2021 10:35:10	Siddhesh Chavan	New		-
Date Time	Technician Name	Status	Remark	Sign																					
08-12-2021 10:44:38	Siddhesh Chavan	Completed	new 2 12v 7 Ah backup battery install and fire panel battery status healthy																						
08-12-2021 10:35:22	Siddhesh Chavan	New		-																					
08-12-2021 10:35:10	Siddhesh Chavan	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>28-12-2021 11:09:43</td><td>Siddhesh Chavan</td><td>They have removed the biometric adapter and have connected charger due to which there was ping issue and ping issue resolved and working ok</td></tr><tr><td>08-12-2021 10:34:11</td><td>Siddhesh Chavan</td><td>biometric machines install and working ok and network change satting training to tajmer bhai</td></tr></tbody></table>					Date Time	Technician Name	Remark	28-12-2021 11:09:43	Siddhesh Chavan	They have removed the biometric adapter and have connected charger due to which there was ping issue and ping issue resolved and working ok	08-12-2021 10:34:11	Siddhesh Chavan	biometric machines install and working ok and network change satting training to tajmer bhai											
Date Time	Technician Name	Remark																							
28-12-2021 11:09:43	Siddhesh Chavan	They have removed the biometric adapter and have connected charger due to which there was ping issue and ping issue resolved and working ok																							
08-12-2021 10:34:11	Siddhesh Chavan	biometric machines install and working ok and network change satting training to tajmer bhai																							